

BLD Contract 30251

Update 8.12.24

Restoration On Going next 2 weeks

Working on sidewalk/curb – 2300 S Roman St

Working on excavated/graded – Finish up in area – 1400 S Prieur St

Working on excavated/graded – Finish work in area – 3400 Third St

Working on excavated/graded – Finish work in area– 3500 First St

Begin Manhole Rehab efforts (Vertical adjustments, Replace Frame and Covers) – C&M has begun laying this work out. Underway on replace frame and covers, vertical adjustments.

Remaining work on this contract 3000 block Washington, 2500 block S Tonti, CIPP (scope TBD pending CCTV)

Segments near Five-oh-Fore Golf – Work TBD – tried to line the two short segments 3800 Euphrosine and S Broad and the lining crew reported clear water coming into the manhole (possible leak in the area).