Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
8/14/2011			2701	S MIRO	4TH	SHC LEAD BROKEN	EXCAVATED	200200070602
8/15/2011			2701	S MIRO	4TH	SHC LEAD BROKEN	REPLACED	200200070603
8/3/2011	182-025			S ROMAN	LAFAYETTE	SMH - BRICK REPAIR OF	EXCAVATED	200901496906
1/7/2011			3651	FRANKLIN AV	ACACIA	SHC LEAD BROKEN	EXCAVATED	200902626005
4/18/2011	355-023		N/A	MANDEVILLE	SELMA	SMH - BRICK REPAIR OF	EXCAVATED	201000720903
2/24/2011	543-031	543-030	7553	FOUNDERS CT	INTREPID	SEWER MAIN BROKEN	EXCAVATED	201000926506
2/25/2011	543-031	543-030	7553	FOUNDERS CT	INTREPID	SEWER MAIN BROKEN	REPAIRED	201000926507
3/2/2011			3616	NASHVILLE AV	MC KENNA	SHC LEAD BROKEN	EXCAVATED	201000948502
4/19/2011	224-034		6700BLK	COLBERT	FILMORE AV	SMH - ABOVE GRADE	REPAIRED	201001566901
11/28/2011	247-004		5701	PARIS AV	PRENTISS AV	SMH - BRICK REPAIR OF	REPAIRED	201001596405
11/29/2011	318-001		5701	PARIS AV	PRENTISS AV	SMH - BRICK REPAIR OF	REPAIRED	201001596406
3/30/2011	091-004		4700	TCHOUPITOULAS	VALENCE	SMH - COVER BROKEN/I	REPLACED	201001719701
2/23/2011			4527	BARONNE	CADIZ	SHC LEAD BROKEN	REPLACED	201001810102

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
2/28/2011	298-046		4729	DUPLESSIS	MIRABEAU AV	SMH - COVER BROKEN/I	EXCAVATED	201001853004
4/13/2011	315-023	315-022	4037	VIRGIL BL	ROBERT E LEE BL	SHC LEAD BROKEN	REPAIRED	201001859504
3/11/2011			5933	CHESTNUT	STATE	SHC LEAD BROKEN	REPAIRED	201001883004
2/23/2011	079-016	079-015	415	OCTAVIA	ANNUNCIATION	SHC LEAD BROKEN	REPLACED	201001904102
2/24/2011			311	S CLARK	PALMYRA	SHC LEAD BROKEN	REPLACED	201001964102
3/21/2011	285-044	285-043	1504	ESPLANADE AV	N CLAIBORNE AV	SHC LEAD BROKEN	EXCAVATED	201002009603
3/22/2011	285-044	285-043	1504	ESPLANADE AV	N CLAIBORNE AV	SHC LEAD BROKEN	EXCAVATED	201002009604
5/23/2011	070-005	070-004	1662	STATE	LOYOLA AV	SHC LEAD BROKEN	EXCAVATED	201002052303
5/26/2011	070-005	070-004	1662	STATE	LOYOLA AV	SHC LEAD BROKEN	REPLACED	201002052306
5/25/2011	070-005	070-004	1662	STATE	LOYOLA AV	SHC LEAD BROKEN	EXCAVATED	201002052304
2/17/2011			3701-03	MAGAZINE	AMELIA	SHC LEAD BROKEN	REPLACED	201002062204
4/24/2011			7216	ZIMPEL	BROADWAY	SHC LEAD BROKEN	EXCAVATED	201002066803
3/1/2011			2521-25	MILAN	S ROBERTSON	SHC LEAD BROKEN	REPLACED	201002118402

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
2/9/2011	371-029	371-028	4622	DEMONTLUZIN	LOMBARD	SHC LEAD BROKEN	REPAIRED	201002152003
1/13/2011	287-053	287-054	1481	N MIRO	COLUMBUS	SHC LEAD BROKEN	REPAIRED	201002180802
1/18/2011			27	FINCH	MARCONI DR	SHC - INSTALL NEW FR(	EXCAVATED	201002198402
1/19/2011			27	FINCH	MARCONI DR	SHC - INSTALL NEW FR(	EXCAVATED	201002198403
1/31/2011			27	FINCH	MARCONI DR	SHC LEAD BROKEN	EXCAVATED	201002198407
1/26/2011			27	FINCH	MARCONI DR	SHC - INSTALL NEW FR(	EXCAVATED	201002198404
2/21/2011			5218	ANNUNCIATION	BELLECASTLE	SHC LEAD BROKEN	REPLACED	201002208902
2/23/2011	213-017	210-016	219	HARRISON AV	MILNE BL	SHC LEAD BROKEN	REPAIRED	201002237503
1/4/2011			906-08	LOWERLINE		SHC LEAD BROKEN	REPAIRED	201002243202
2/24/2011	046-022	045-003	7413	SPRUCE	ADAMS	SHC LEAD BROKEN	REPAIRED	201002253202
2/22/2011	194-002	-001	1938	JACKSON AV	DRYADES	SHC LEAD BROKEN	REPAIRED	201002279002
4/12/2011			1829	LEONIDAS	HICKORY	SHC LEAD BROKEN	REPAIRED	201002313102
2/28/2011			5617	PRYTANIA	ARABELLA	SHC LEAD BROKEN	REPLACED	201002321103

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
5/4/2011	105-020	105-019	4123	S SARATOGA	MILAN	SHC LEAD BROKEN	REPAIRED	201002322803
1/24/2011		177-024	109	TCHOUPITOULAS	CANAL	SHC LEAD BROKEN	EXCAVATED	201002324002
1/25/2011		177-024	109	TCHOUPITOULAS	CANAL	SHC LEAD BROKEN	REPAIRED	201002324003
1/20/2011			3022	1ST	S CLAIBORNE AV	SHC LEAD BROKEN	REPLACED	201002352602
4/12/2011			2012	JENA	DANNEEL	SHC LEAD BROKEN	REPAIRED	201002369502
1/19/2011			3320	ST PETER	HAGAN AL	SHC - INSTALL NEW FR(	EXCAVATED	201002377301
1/20/2011			3320	ST PETER	HAGAN AL	SHC - INSTALL NEW FR(	REPAIRED	201002377302
2/10/2011			2818	ERATO	CLARA	SHC - INSTALL NEW FR(	EXCAVATED	201002377401
2/8/2011			8812	APPLE	EAGLE	SHC LEAD BROKEN	REPAIRED	201002394503
1/7/2011	133-061	133-060	3401	S BROAD	ELBA	SHC LEAD BROKEN	REPAIRED	201002401002
4/7/2011			2629	FELICITY	CLARA	SHC LEAD BROKEN	REPAIRED	201002429202
2/14/2011			906	PICHELOUP PL	DUMAINE	SHC LEAD BROKEN	REPAIRED	201002447202
1/6/2011	035-002	036-013	2711	SHORT	BELFAST	SHC LEAD BROKEN	REPAIRED	201002459502

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
2/14/2011			601	LOYOLA AV	POYDRAS	SHC LEAD BROKEN	EXCAVATED	201002473901
2/15/2011			601	LOYOLA AV	POYDRAS	SHC LEAD BROKEN	REPAIRED	201002473902
2/16/2011			601	LOYOLA AV	POYDRAS	SHC LEAD BROKEN	REPAIRED	201002473903
3/14/2011	309-002	309-001	1872	N MIRO	ALLEN	SHC LEAD BROKEN	REPAIRED	201002515602
1/5/2011	079-037	079-036	417	ELEONORE	ANNUNCIATION	SEWER MAIN BROKEN	EXCAVATED	201002522003
1/6/2011	079-037	079-036	417	ELEONORE	ANNUNCIATION	SEWER MAIN BROKEN	REPAIRED	201002522004
7/11/2011			626-28	N RAMPART		SHC - INSTALL NEW FR(	EXCAVATED	201002533403
7/12/2011			626-28	N RAMPART		SHC - INSTALL NEW FR(	REPAIRED	201002533404
2/27/2011	235-045		6823	GEN HAIG	CHAPELLE	SMH - COVER BROKEN/I	REPAIRED	201002559701
1/1/2011			8332	S CLAIBORNE AV	DANTE	SHC LEAD BROKEN	EXCAVATED	201002577902
1/9/2011			8332	S CLAIBORNE AV	DANTE	SHC LEAD BROKEN	REPAIRED	201002577903
6/6/2011	081-032	081-031	5520	PITT	LEONTINE	SEWER MAIN BROKEN	EXCAVATED	201002582204
6/7/2011	081-032	081-031	5520	PITT	LEONTINE	SEWER MAIN BROKEN	EXCAVATED	201002582205

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
6/9/2011	081-032	081-031	5520	PITT	LEONTINE	SEWER MAIN BROKEN	REPLACED	201002582207
6/5/2011	081-032	081-031	5520	PITT	LEONTINE	SHC LEAD BROKEN	EXCAVATED	201002582203
6/8/2011	081-032	081-031	5520	PITT	LEONTINE	SEWER MAIN BROKEN	EXCAVATED	201002582206
2/21/2011			9016	PEAR	HAMILTON	SHC - INSTALL NEW FR(	REPAIRED	201002587901
2/21/2011			9016	PEAR	HAMILTON	SHC - INSTALL NEW FR(	REPAIRED	201002587902
1/12/2011			5268	LAUREL	VALMONT	SHC LEAD BROKEN	EXCAVATED	201002588602
1/13/2011			5268	LAUREL	VALMONT	SHC LEAD BROKEN	REPLACED	201002588603
3/16/2011	291-034		2917	LEPAGE	N DUPRE	SHC LEAD BROKEN	EXCAVATED	201002592202
3/18/2011	291-034		2917	LEPAGE	N DUPRE	SHC LEAD BROKEN	REPAIRED	201002592206
3/17/2011	291-034		2917	LEPAGE	N DUPRE	SHC LEAD BROKEN	EXCAVATED	201002592205
1/20/2011			211	W BROOKS	FLEUR DE LIS DR	SHC LEAD BROKEN	EXCAVATED	201002593303
1/21/2011			211	W BROOKS	FLEUR DE LIS DR	SHC LEAD BROKEN	EXCAVATED	201002593304
1/24/2011			211	W BROOKS	FLEUR DE LIS DR	SHC LEAD BROKEN	REPAIRED	201002593305

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
1/17/2011	034-008	034-007	8134	SYCAMORE	DUBLIN	SHC LEAD BROKEN	REPAIRED	201002603202
1/10/2011			8718	APPLE	MONROE	SHC LEAD BROKEN	REPAIRED	201002604302
1/15/2011	240-014	240-013	3600	DUMAINE	MOSS	SEWER MAIN BROKEN	EXCAVATED	201002608202
1/16/2011	240-014	240-013	3600	DUMAINE	MOSS	SEWER MAIN BROKEN	REPAIRED	201002608203
2/7/2011			6326	BRIGHTON PL	SIMPSON PL	SHC LEAD BROKEN	EXCAVATED	201002616302
2/8/2011			6326	BRIGHTON PL	SIMPSON PL	SHC LEAD BROKEN	REPAIRED	201002616304
2/2/2011	130-014	130-013	2515	MAGNOLIA	3RD	SHC LEAD BROKEN	EXCAVATED	201100000102
2/3/2011	130-014	130-013	2515	MAGNOLIA	3RD	SHC LEAD BROKEN	REPAIRED	201100000104
1/4/2011			1971	N ROCHEBLAVE		SHC LEAD BROKEN	EXCAVATED	201100001902
1/7/2011			1971	N ROCHEBLAVE		SHC LEAD BROKEN	REPAIRED	201100001903
1/18/2011			6165	LOUIS XIV	GERMAIN	SHC LEAD BROKEN	EXCAVATED	201100002302
1/6/2011			3344	GENTILLY BL	CLEMATIS	SHC LEAD BROKEN	REPAIRED	201100002701
6/5/2011			2838	ANNUNCIATION	6TH	SHC LEAD BROKEN	EXCAVATED	201100003102

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
6/6/2011			2838	ANNUNCIATION	6TH	SHC LEAD BROKEN	REPAIRED	201100003103
2/17/2011			2143	HOPE	TOURO	SHC - INSTALL NEW FR(	REPAIRED	201100016001
3/1/2011			2143	HOPE	TOURO	SHC - INSTALL NEW FR(	REPAIRED	201100016006
1/6/2011	138-060	138-058	1022	JOSEPHINE	ST ALPHONSE AL	SEWER MAIN BROKEN	EXCAVATED	201100016104
1/7/2011	138-060	138-058	1022	JOSEPHINE	ST ALPHONSE AL	SEWER MAIN BROKEN	REPAIRED	201100016105
1/8/2011			9032	FIG	HAMILTON	SHC LEAD BROKEN	REPAIRED	201100022402
1/10/2011			4325	SEMINARY PL	MIRABEAU AV	SHC LEAD BROKEN	REPAIRED	201100039504
1/12/2011			5332	PASTEUR BL	FILMORE AV	SHC LEAD BROKEN	REPAIRED	201100044202
1/9/2011			5332	PASTEUR BL	FILMORE AV	SHC LEAD BROKEN	EXCAVATED	201100044203
1/11/2011	298-027	298-026	1448	OWENS BL	CARTIER AV	SHC LEAD BROKEN	EXCAVATED	201100051702
2/3/2011			8141	APRICOT	DUBLIN	SHC LEAD BROKEN	EXCAVATED	201100063005
2/22/2011			8141	APRICOT	DUBLIN	SHC LEAD BROKEN	REPAIRED	201100063006
1/18/2011			1831	HERMOSA	MAGELLAN	SHC LEAD BROKEN	EXCAVATED	201100065402

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
1/19/2011			1831	HERMOSA	MAGELLAN	SHC LEAD BROKEN	REPAIRED	201100065403
4/13/2011			5321	WARRINGTON DR	FILMORE AV	SHC LEAD BROKEN	EXCAVATED	201100067502
4/14/2011			5321	WARRINGTON DR	FILMORE AV	SHC LEAD BROKEN	REPAIRED	201100067503
1/13/2011	199-017	199-011	2022-24	BIENVILLE	N PRIEUR	SHC LEAD BROKEN	REPAIRED	201100070403
1/29/2011	081-032	081-031	N / A	OCTAVIA	PITT	SEWER MAIN BROKEN	REPAIRED	201100070603
1/28/2011	081-032	081-031	N / A	OCTAVIA	PITT	SEWER MAIN BROKEN	EXCAVATED	201100070604
1/29/2011	081-032	081-031	N / A	OCTAVIA	PITT	SEWER MAIN BROKEN	REPAIRED	201100070605
1/30/2011	081-032	081-031	N / A	OCTAVIA	PITT	SEWER MAIN BROKEN	REPAIRED	201100070606
4/9/2011	001-009	001-008	3800	EAGLE	PALMETTO	SEWER MAIN BROKEN	REPAIRED	201100072705
1/31/2011			319	GERMAIN	MILNE BL	SHC LEAD BROKEN	REPAIRED	201100074801
1/15/2011		-050	2752	CANAL	S WHITE	SHC LEAD BROKEN	EXCAVATED	201100080802
1/18/2011			2752	CANAL	S WHITE	SHC LEAD BROKEN	REPAIRED	201100080803
1/16/2011			1001	N BROAD	ST PHILIP	SHC LEAD BROKEN	EXCAVATED	201100085302

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
1/18/2011			1001	N BROAD	ST PHILIP	SHC LEAD BROKEN	REPAIRED	201100085303
2/2/2011			1001	N BROAD	ST PHILIP	SHC LEAD BROKEN	REPAIRED	201100085308
2/1/2011			1001	N BROAD	ST PHILIP	SHC LEAD BROKEN	EXCAVATED	201100085307
1/16/2011			4659	BONITA DR	LEEDS	SHC LEAD BROKEN	EXCAVATED	201100086002
1/19/2011			4659	BONITA DR	LEEDS	SHC LEAD BROKEN	REPAIRED	201100086003
1/16/2011			6808	COLBERT	CHAPELLE	SHC LEAD BROKEN	EXCAVATED	201100086102
2/1/2011			6808	COLBERT	CHAPELLE	SHC LEAD BROKEN	REPAIRED	201100086103
1/18/2011			4534	EASTVIEW DR	GRANT AV	SHC LEAD BROKEN	REPAIRED	201100086702
1/18/2011			429	S SCOTT	BAUDIN	SHC LEAD BROKEN	EXCAVATED	201100087802
1/19/2011			429	S SCOTT	BAUDIN	SHC LEAD BROKEN	REPAIRED	201100087803
2/7/2011	473-063	473-062	4626	ROSALIA DR	GRANT	SHC LEAD BROKEN	EXCAVATED	201100089803
2/8/2011	473-063	473-062	4626	ROSALIA DR	GRANT	SHC LEAD BROKEN	REPAIRED	201100089804
2/6/2011			731	PACIFIC AV	SLIDELL AV	SHC LEAD BROKEN	REPAIRED	201100105602

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
1/21/2011			1813	DESIRE		SHC LEAD BROKEN	EXCAVATED	201100113202
1/26/2011			1813	DESIRE		SHC LEAD BROKEN	REPAIRED	201100113205
1/24/2011			1813	DESIRE		SHC LEAD BROKEN	EXCAVATED	201100113203
1/25/2011			1813	DESIRE		SHC LEAD BROKEN	EXCAVATED	201100113204
2/5/2011			737	PACIFIC AV	SLIDELL	SHC LEAD BROKEN	REPAIRED	201100113402
5/31/2011	306-059	306-056	1709	N BROAD	D"ABADIE	SHC LEAD BROKEN	REPAIRED	201100114103
1/21/2011			400	N BROAD	CONTI	SHC LEAD BROKEN	EXCAVATED	201100114802
1/25/2011			400	N BROAD	CONTI	SHC LEAD BROKEN	EXCAVATED	201100114803
5/10/2011	006-022	006-021	232	FAIRWAY DR	ETHEL LN	SHC LEAD BROKEN	REPAIRED	201100117903
5/18/2011			5322	WILTON DR	FILMORE AV	SHC LEAD BROKEN	REPAIRED	201100120703
2/27/2011	194-035		4333	BANKS	S ALEXANDER	SMH - COVER BROKEN/I	REPAIRED	201100125101
1/23/2011			5200	ST CLAUDE AV	LIZARDI	SHC LEAD BROKEN	EXCAVATED	201100125902
1/28/2011			5200	ST CLAUDE AV	LIZARDI	SHC LEAD BROKEN	EXCAVATED	201100125904

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
1/27/2011			5200	ST CLAUDE AV	LIZARDI	SHC LEAD BROKEN	EXCAVATED	201100125903
1/27/2011			6138	VICKSBURG	GERMAIN	SHC LEAD BROKEN	EXCAVATED	201100129702
1/28/2011			6138	VICKSBURG	GERMAIN	SHC LEAD BROKEN	REPAIRED	201100129703
7/11/2011			2705	PENISTON	CLARA	SHC - INSTALL NEW FR(	EXCAVATED	201100136601
4/14/2011			2414	CHARBONNET	N ROCHEBLAVE	SHC - INSTALL NEW FR(	EXCAVATED	201100136801
6/23/2011			2414	CHARBONNET	N ROCHEBLAVE	SHC - INSTALL NEW FR(	EXCAVATED	201100136803
2/19/2011			1704	ODEON AV	BRINGIER	SHC - INSTALL NEW FR(	EXCAVATED	201100137101
1/24/2011			932	WASHINGTON AV	CONSTANCE	SEE WHY NO WATER	REPLACED	201100139701
1/24/2011			932	WASHINGTON AV	CONSTANCE	SEE WHY NO WATER	REPLACED	201100139801
2/13/2011			7204	HICKORY	BROADWAY	SHC LEAD BROKEN	REPAIRED	201100140202
2/11/2011			318	N LOPEZ		SHC LEAD BROKEN	EXCAVATED	201100140802
3/23/2011			318	N LOPEZ	BIENVILLE	SHC LEAD BROKEN	REPAIRED	201100140806
2/15/2011			318	N LOPEZ		SHC LEAD BROKEN	EXCAVATED	201100140803

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
2/16/2011			318	N LOPEZ		SHC LEAD BROKEN	REPAIRED	201100140804
4/4/2011			330	N LOPEZ	BIENVILLE	SHC - INSTALL NEW FR(	REPAIRED	201100141003
8/2/2011			2325	FELICITY	FRERET	SHC - INSTALL NEW FR(	EXCAVATED	201100141601
8/3/2011			2325	FELICITY	FRERET	SHC - INSTALL NEW FR(	EXCAVATED	201100141602
7/13/2011			2729	JACKSON AV	WILLOW	SHC - INSTALL NEW FR(	EXCAVATED	201100141901
1/25/2011			5413	FRANKLIN AV	MITHRA	SHC LEAD BROKEN	REPAIRED	201100144102
2/1/2011			9037	FIG	HAMILTON	SHC LEAD BROKEN	REPAIRED	201100146102
4/21/2011			3012	ST PETER	N GAYOSO	SHC LEAD BROKEN	REPAIRED	201100153503
1/28/2011	460-P5	460-P3	N/A	DWYER BL	AMERICA	SEWER LEAK - FORCE M	EXCAVATED	201100155201
1/31/2011	460-P5	460-P3	N/A	DWYER BL	AMERICA	SEWER LEAK - FORCE M	EXCAVATED	201100155203
4/12/2011			2416	CHARBONNET	N DORGENOIS	SHC - INSTALL NEW FR(	EXCAVATED	201100157301
6/22/2011			2416	CHARBONNET	N DORGENOIS	SHC - INSTALL NEW FR(	EXCAVATED	201100157304
6/27/2011			2416	CHARBONNET	N DORGENOIS	SHC - INSTALL NEW FR(	EXCAVATED	201100157306

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
6/28/2011			2416	CHARBONNET	N DORGENOIS	SHC - INSTALL NEW FR(	EXCAVATED	201100157308
6/24/2011			2416	CHARBONNET	N DORGENOIS	SHC - INSTALL NEW FR(	EXCAVATED	201100157305
4/13/2011			2416	CHARBONNET	N DORGENOIS	SHC - INSTALL NEW FR(	EXCAVATED	201100157302
2/19/2011			1700	ODEON AV	BRINGIER	SHC - INSTALL NEW FR(	EXCAVATED	201100157601
2/1/2011			2241	TOLEDANO	S LIBERTY	SHC LEAD BROKEN	REPAIRED	201100158002
1/28/2011			1535	TITA	LAWRENCE ST	SHC LEAD BROKEN	EXCAVATED	201100158803
1/31/2011			1535	TITA	LAWRENCE ST	SHC LEAD BROKEN	EXCAVATED	201100158804
2/1/2011			1535	TITA	LAWRENCE ST	SHC LEAD BROKEN	REPAIRED	201100158805
3/23/2011			4718	CONGRESS DR	STEPHEN GIRARD AV	SHC LEAD BROKEN	REPAIRED	201100163602
3/7/2011	237-116	237-115	10	RAIL	TERN	SHC LEAD BROKEN	EXCAVATED	201100164802
3/10/2011	237-116	237-115	10	RAIL	TERN	SHC LEAD BROKEN	EXCAVATED	201100164803
1/30/2011	299-013	299-012	4642	OWENS BL	MIRABEAU AV	SHC LEAD BROKEN	EXCAVATED	201100165202
2/2/2011			4642	OWENS BL	MIRABEAU AV	SHC LEAD BROKEN	REPAIRED	201100165204

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
1/30/2011			5922	FLORIDA AV	ROFFIGNAC	SHC LEAD BROKEN	REPAIRED	201100165502
1/28/2011			2037	N BROAD	DUELS	SHC LEAD BROKEN	REPAIRED	201100173301
5/3/2011	133-040	133-038	1331	S BROAD	ERATO	SHC LEAD BROKEN	REPAIRED	201100175203
2/1/2011			1110	BURGUNDY	URSULINES AV	SHC LEAD BROKEN	REPAIRED	201100177503
2/2/2011			6165	LOUIS XIV	FRENCH	SHC LEAD BROKEN	REPAIRED	201100181102
6/4/2011	134-059	134-054	1803	S DUPRE	ELBA	SHC LEAD BROKEN	REPLACED	201100183402
2/3/2011			6131	DOVER PL	AURORA DR	SHC LEAD BROKEN	REPAIRED	201100187002
2/2/2011			3253-55	ANNUNCIATION	TOLEDANO	SHC LEAD BROKEN	EXCAVATED	201100187702
2/8/2011			3253-55	ANNUNCIATION	TOLEDANO	SHC LEAD BROKEN	REPAIRED	201100187703
7/17/2011	143-042	143-041	2717	JOSEPHINE	CLARA	SHC - INSTALL NEW FR(	EXCAVATED	201100188701
2/11/2011			8636	PEAR	MONROE	SHC LEAD BROKEN	REPAIRED	201100189302
2/15/2011			2124	S SARATOGA		SHC LEAD BROKEN	REPAIRED	201100195202
7/22/2011	145-039	145-038	3718	1ST	S TONTI	SHC - INSTALL NEW FR(	EXCAVATED	201100198802

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
5/8/2011			2100-02	PACE BL	SANDRA DR	SHC - INSTALL NEW FR(	EXCAVATED	201100199501
5/9/2011			2100-02	PACE BL	SANDRA DR	SHC - INSTALL NEW FR(	EXCAVATED	201100199502
5/10/2011			2100-02	PACE BL	SANDRA DR	SHC - INSTALL NEW FR(	EXCAVATED	201100199503
2/7/2011			9037	FIG	HOLLYGROVE	SHC LEAD BROKEN	REPAIRED	201100201102
2/9/2011			3539	ST CHARLES AV	FOUCHER	SHC LEAD BROKEN	REPAIRED	201100208102
2/9/2011			3501	ROGER WILLIAM!	YUPON	SHC LEAD BROKEN	REPAIRED	201100217502
2/9/2011	203-025	202-040	3300	BIENVILLE	N RENDON	SHC LEAD BROKEN	REPAIRED	201100220002
2/9/2011			2200	DESIRE	N MIRO	SHC LEAD BROKEN	EXCAVATED	201100222402
2/10/2011			2200	DESIRE	N MIRO	SHC LEAD BROKEN	REPAIRED	201100222403
2/9/2011			1230	HENDEE	LAMARQUE	SHC LEAD BROKEN	REPAIRED	201100223302
2/14/2011			5520	PITT	OCTAVIA	SHC LEAD BROKEN	REPAIRED	201100230004
2/14/2011			175	DANNY DR	HUNTLEE DR	SHC LEAD BROKEN	REPAIRED	201100246802
2/15/2011			5701	PROVIDENCE PL		SHC LEAD BROKEN	REPAIRED	201100250002

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
2/14/2011	0	0		DWYER RD	DOWNMAN RD	SEWER LEAK - FORCE M	REPAIRED	201100252601
5/2/2011			5310	ST ANTHONY AV		SHC LEAD BROKEN	REPAIRED	201100254103
10/13/2011			6044	CONSTANCE	WEBSTER	SHC LEAD BROKEN	EXCAVATED	201100261203
3/31/2011	486-066	486-065	14433	CHEF MENTEUR H	ALCEE FORTIER BL	SMH - BRICK REPAIR OF	EXCAVATED	201100262403
4/1/2011	486-066	486-065	14433	CHEF MENTEUR H	ALCEE FORTIER BL	SMH - BRICK REPAIR OF	EXCAVATED	201100262404
4/2/2011	486-066	486-065	14433	CHEF MENTEUR H	ALCEE FORTIER BL	SMH - BRICK REPAIR OF	REPAIRED	201100262405
2/16/2011	486-066	486-065	14433	CHEF MENTEUR H	ALCEE FORTIER BL	SEWER MAIN BROKEN	REPAIRED	201100262401
3/15/2011			520	NASHVILLE AV	LAUREL	SHC LEAD BROKEN	EXCAVATED	201100273903
2/21/2011			5312	PASTEUR BL	FILMORE AV	SHC LEAD BROKEN	EXCAVATED	201100287802
2/22/2011			5312	PASTEUR BL	FILMORE AV	SHC LEAD BROKEN	REPAIRED	201100287804
2/22/2011			6050	LAUREL	WEBSTER	SHC LEAD BROKEN	EXCAVATED	201100289502
2/23/2011			6050	LAUREL	WEBSTER	SHC LEAD BROKEN	EXCAVATED	201100289503
2/23/2011			6050	LAUREL	WEBSTER	SHC LEAD BROKEN	REPAIRED	201100289504

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
2/18/2011			2141	PORT	N MIRO	SHC LEAD BROKEN	EXCAVATED	201100297002
2/23/2011			2141	PORT	N MIRO	SHC LEAD BROKEN	EXCAVATED	201100297003
2/26/2011			2141	PORT	N MIRO	SHC LEAD BROKEN	REPAIRED	201100297006
2/24/2011			2141	PORT	N MIRO	SHC LEAD BROKEN	EXCAVATED	201100297005
2/25/2011			5200	ANNUNCIATION	DUFOSSAT	SHC LEAD BROKEN	REPAIRED	201100298302
2/21/2011	405-030		2341-43	DESIRE	N ROCHEBLAVE	SHC LEAD BROKEN	EXCAVATED	201100299203
2/25/2011	405-030		2341-43	DESIRE	N ROCHEBLAVE	SHC LEAD BROKEN	EXCAVATED	201100299206
2/27/2011	405-030		2341-43	DESIRE	N ROCHEBLAVE	SHC LEAD BROKEN	REPAIRED	201100299207
2/22/2011	405-030		2341-43	DESIRE	N ROCHEBLAVE	SHC LEAD BROKEN	EXCAVATED	201100299204
2/19/2011			8624	APPLE	LEONIDAS	SHC LEAD BROKEN	EXCAVATED	201100306502
3/21/2011			8624	APPLE	LEONIDAS	SHC LEAD BROKEN	REPAIRED	201100306503
3/22/2011			8626	APPLE	LEONIDAS	SHC LEAD BROKEN	REPAIRED	201100306504
3/21/2011			929	HOMER	PACIFIC AV	SHC LEAD BROKEN	EXCAVATED	201100307301

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
3/22/2011			929	HOMER	PACIFIC AV	SHC LEAD BROKEN	REPAIRED	201100307302
2/21/2011	121-019	121-015	1908	7TH	DRYADES	SHC LEAD BROKEN	REPAIRED	201100308605
2/22/2011			3609	STATE STREET DI		SHC LEAD BROKEN	REPAIRED	201100309802
4/8/2011			4508	FIESTA	KABEL DR	SHC LEAD BROKEN	REPAIRED	201100320702
5/20/2011	313-006		3405	PARIS AV		SMH - BRICK REPAIR OF	REPAIRED	201100322502
5/6/2011			4816	DREXEL DR	S GENOIS	SHC LEAD BROKEN	REPAIRED	201100322902
2/22/2011			4782	CITRUS DR	HAMMOND	SHC LEAD BROKEN	EXCAVATED	201100328402
2/23/2011			4782	CITRUS DR	HAMMOND	SHC LEAD BROKEN	REPAIRED	201100328403
2/24/2011			1828	LOUISA	N ROMAN	SHC LEAD BROKEN	REPAIRED	201100334503
2/25/2011	033-003	033-001	7913	COHN	FERN	SHC LEAD BROKEN	REPAIRED	201100338203
3/1/2011	172-001	172-013	941	LAFAYETTE AL	O"KEEFE AV	SHC LEAD BROKEN	REPAIRED	201100345202
3/11/2011			5831	PAULINE DR	PRENTISS AV	SHC LEAD BROKEN	EXCAVATED	201100349803
3/15/2011			5831	PAULINE DR	MADRID	SHC LEAD BROKEN	EXCAVATED	201100349804

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
3/16/2011			5831	PAULINE DR	MADRID	SHC LEAD BROKEN	REPAIRED	201100349805
2/26/2011	028-006	-001	3726	EAGLE	STROELITZ	SHC LEAD BROKEN	EXCAVATED	201100351702
4/4/2011	028-006	-001	3726	EAGLE	STROELITZ	SHC LEAD BROKEN	EXCAVATED	201100351703
4/5/2011	028-006	-001	3726	EAGLE	STROELITZ	SHC LEAD BROKEN	REPAIRED	201100351704
2/27/2011	465-053	465-052	4657	BONITA DR	LEEDS	SHC LEAD BROKEN	EXCAVATED	201100352603
3/1/2011	465-053	465-052	4657	BONITA DR	LEEDS	SHC LEAD BROKEN	REPAIRED	201100352604
3/14/2011			6808-10	COLBERT	CHAPELLE	SHC LEAD BROKEN	EXCAVATED	201100353102
2/28/2011			1824	CONGRESS	N ROMAN	SHC LEAD BROKEN	REPAIRED	201100354102
2/27/2011			3231	MILAN	S PRIEUR	SHC LEAD BROKEN	REPLACED	201100354702
2/28/2011			1738	REYNES	N DERBIGNY	SHC LEAD BROKEN	REPAIRED	201100360302
3/1/2011			3909	BIENVILLE	N SCOTT	SHC LEAD BROKEN	EXCAVATED	201100364302
2/4/2011			3909	BIENVILLE	N SCOTT	SHC LEAD BROKEN	REPAIRED	201100364305
3/2/2011			3909	BIENVILLE	N SCOTT	SHC LEAD BROKEN	EXCAVATED	201100364303

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
3/15/2011			6334	LOUISVILLE	HARRISON AV	SHC LEAD BROKEN	REPAIRED	201100365305
3/2/2011			2658	ROBERT E LEE BL		SHC LEAD BROKEN	EXCAVATED	201100368402
3/1/2011	0	0	5744	PRESS DR		SHC LEAD BROKEN	EXCAVATED	201100371502
3/3/2011			1270	FOY	BUCHANAN	SHC LEAD BROKEN	EXCAVATED	201100372902
3/4/2011			1270	FOY	BUCHANAN	SHC LEAD BROKEN	REPAIRED	201100372903
3/3/2011			1627	FORSTALL	N DERBIGNY	SHC LEAD BROKEN	EXCAVATED	201100381702
3/4/2011			1627	FORSTALL	N DERBIGNY	SHC LEAD BROKEN	REPAIRED	201100381703
4/18/2011	191-024	191-022	3136	FORTIN	N LOPEZ	SHC LEAD BROKEN	EXCAVATED	201100388102
4/19/2011	191-024	191-022	3136	FORTIN	N LOPEZ	SHC LEAD BROKEN	REPAIRED	201100388103
3/5/2011			5918	ELYSIAN FIELDS .	BURBANK DR	SHC LEAD BROKEN	EXCAVATED	201100390203
3/6/2011			9032	FIG	HAMILTON	SHC LEAD BROKEN	EXCAVATED	201100397002
3/17/2011			9032	FIG		SHC LEAD BROKEN	REPAIRED	201100397003
3/7/2011			4931	S ROCHEBLAVE	UPPERLINE	SHC LEAD BROKEN	REPAIRED	201100399102

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
4/19/2011			2229	ALLEN	N MIRO	SHC LEAD BROKEN	REPAIRED	201100401502
3/10/2011	177-024	-025	111	TCHOUPITOULAS	CANAL	SHC LEAD BROKEN	EXCAVATED	201100409903
3/11/2011	177-024	-025	111	TCHOUPITOULAS	CANAL	SHC LEAD BROKEN	REPAIRED	201100409905
3/10/2011	177-024	-025	111	TCHOUPITOULAS	CANAL	SHC LEAD BROKEN	EXCAVATED	201100409904
4/25/2011			3605	4TH	S MIRO	SHC - INSTALL NEW FR(	EXCAVATED	201100413801
4/27/2011			3605	4TH	S MIRO	SHC - INSTALL NEW FR(	REPAIRED	201100413804
3/29/2011			4209	S CLAIBORNE AV	MILAN	SHC LEAD BROKEN	REPAIRED	201100419402
3/17/2011	183-017	183-012	2208	GRAVIER	S GALVEZ	SHC LEAD BROKEN	EXCAVATED	201100423202
3/18/2011	183-017	183-012	2208	GRAVIER	S GALVEZ	SHC LEAD BROKEN	REPAIRED	201100423203
3/13/2011			6440	CANAL BL	LANE	SHC LEAD BROKEN	EXCAVATED	201100425302
3/16/2011			6650	VIRGILIAN		SHC LEAD BROKEN	EXCAVATED	201100429402
3/17/2011			6650	VIRGILIAN		SHC LEAD BROKEN	REPAIRED	201100429403
3/15/2011			4429	CLARA	JENA	SHC LEAD BROKEN	REPAIRED	201100435202

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
5/4/2011			1922	OLD PRIEUR	NEW ORLEANS	SHC - INSTALL NEW FR(	REPAIRED	201100435701
3/25/2011			6753-55	BELLAIRE DR		SHC LEAD BROKEN	REPAIRED	201100442802
8/17/2011	125-010	125-009	2833	CONSTANCE	WASHINGTON AV	SHC LEAD BROKEN	REPAIRED	201100447002
3/19/2011			2478	JASMINE	IRIS	SHC LEAD BROKEN	REPAIRED	201100451303
3/17/2011			2237	POYDRAS	S BROAD	SHC - OVERFLOWING	EXCAVATED	201100452401
4/4/2011		A7-116	1226	SHIRLEY DR	DE ARMAS	SHC LEAD BROKEN	REPAIRED	201100452803
5/6/2011	354-026	(086)-017	4735	PAINTERS	MIRABEAU AV	SMH - COVER BROKEN/I	REPAIRED	201100458301
3/19/2011			3217	UPPERLINE	S PRIEUR	SHC LEAD BROKEN	EXCAVATED	201100466202
3/22/2011			3217	UPPERLINE	JEFFERSON AV	SHC LEAD BROKEN	REPAIRED	201100466203
3/19/2011			4834	GAWAIN DR	HAMMOND	SHC LEAD BROKEN	EXCAVATED	201100466502
3/21/2011			4834	GAWAIN DR	DWYER BL	SHC LEAD BROKEN	REPAIRED	201100466503
3/20/2011			3110	ROBERT	S JOHNSON	SHC LEAD BROKEN	EXCAVATED	201100467702
3/25/2011			3110	ROBERT	S PRIEUR	SHC LEAD BROKEN	REPLACED	201100467703

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
3/22/2011			4726	FRENCHMEN	BRUTUS	SHC LEAD BROKEN	REPAIRED	201100471102
3/26/2011	207-012	195-018		JULIA	BANKS	SEWER MAIN BROKEN	REPAIRED	201100480202
5/17/2011	289-002	289-017	3009-11	ST PHILIP	N GAYOSO	SHC LEAD BROKEN	REPAIRED	201100483403
4/29/2011			711	BOURBON	ST ANN	SHC LEAD BROKEN	REPAIRED	201100484002
4/5/2011			1218	SONIAT	PERRIER	SHC LEAD BROKEN	EXCAVATED	201100488202
4/6/2011			1218	SONIAT	PERRIER	SHC LEAD BROKEN	REPAIRED	201100488203
3/28/2011	089-019	089-017	5000	LOYOLA AV	ROBERT	SEWER MAIN BROKEN	REPAIRED	201100490402
3/26/2011			4417	ULLOA	N ALEXANDER	SHC LEAD BROKEN	EXCAVATED	201100509302
4/26/2011			4417	ULLOA	N ALEXANDER	SHC LEAD BROKEN	REPAIRED	201100509303
7/20/2011			3116-18	TOLEDANO	S ROMAN	SHC LEAD BROKEN	REPAIRED	201100513202
6/9/2011			3420-22	NASHVILLE AV	S ROCHEBLAVE	SHC - INSTALL NEW FR(	REPAIRED	201100514402
3/28/2011	199-029	199-030	2022	BIENVILLE	N JOHNSON	SHC LEAD BROKEN	EXCAVATED	201100516702
3/29/2011	199-029	199-030	2022	BIENVILLE	N JOHNSON	SHC LEAD BROKEN	REPAIRED	201100516704

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
4/5/2011			3508	ROBERT	S MIRO	SHC LEAD BROKEN	REPAIRED	201100536503
4/6/2011			5936	LOUISVILLE	POLK	SHC LEAD BROKEN	REPAIRED	201100540302
4/2/2011			229	S ROCHEBLAVE	CLEVELAND AV	SHC LEAD BROKEN	EXCAVATED	201100547203
4/5/2011			227-29	S ROCHEBLAVE	CLEVELAND AV	SHC LEAD BROKEN	EXCAVATED	201100547205
4/13/2011	327-012	372-011	2632-34	DREUX AV	DEMONTLUZIN	SHC LEAD BROKEN	REPAIRED	201100547904
4/2/2011			720	EVELINA	VALLETTE	SHC LEAD BROKEN	REPAIRED	201100548302
4/4/2011			720	EVELINA	VALLETTE	SHC LEAD BROKEN	REPAIRED	201100548303
7/6/2011	116-030	116-029	3428	LASALLE	LOUISIANA AV	SHC - INSTALL NEW FR(	EXCAVATED	201100550303
7/5/2011			3428	LASALLE	LOUISIANA AV	SHC - INSTALL NEW FR(	EXCAVATED	201100550301
5/5/2011			1320	ST ANDREW	COLISEUM	SHC LEAD BROKEN	REPAIRED	201100552904
4/12/2011	524-004	524-003	5	ACADIANA PL	WILLOWBROOK DR	SHC LEAD BROKEN	REPAIRED	201100553904
4/7/2011			8917	OLIVE	GEN OGDEN	SHC LEAD BROKEN	REPAIRED	201100565902
4/15/2011	225-013	225-009	7019	LOUIS XIV	WALKER	SHC LEAD BROKEN	REPAIRED	201100567203

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
5/3/2011			1207	SPAIN	URQUHART	SHC LEAD BROKEN	REPAIRED	201100568802
9/15/2011	125-026	125-013	815	WASHINGTON AV	ANNUNCIATION	SEWER MAIN BROKEN	EXCAVATED	201100571203
9/16/2011	125-026	125-013	815	WASHINGTON AV		SEWER MAIN BROKEN	EXCAVATED	201100571205
9/20/2011	125-026	125-013	815	WASHINGTON AV		SEWER MAIN BROKEN	EXCAVATED	201100571207
9/21/2011	125-026	125-013	815	WASHINGTON AV		SEWER MAIN BROKEN	REPAIRED	201100571208
9/19/2011	125-026	125-013	815	WASHINGTON AV		SEWER MAIN BROKEN	EXCAVATED	201100571206
4/7/2011			2348	FORSTALL	N ROCHEBLAVE	SHC LEAD BROKEN	REPAIRED	201100577201
4/8/2011			400	N BROAD		SHC LEAD BROKEN	EXCAVATED	201100581202
4/11/2011			400	N BROAD		SHC LEAD BROKEN	REPAIRED	201100581204
4/10/2011			5631	MILNE BL	HOMEDALE	SHC LEAD BROKEN	REPAIRED	201100585902
4/16/2011	479-017	479-016	N/A	CHEF MENTEUR H	CHANTILLY DR	SEWER MAIN BROKEN	EXCAVATED	201100606404
4/17/2011	479-017	479-016	N/A	CHEF MENTEUR H	CHANTILLY DR	SEWER MAIN BROKEN	REPAIRED	201100606405
4/13/2011			1329	TECHE		SHC LEAD BROKEN	EXCAVATED	201100610603

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
4/14/2011			1329	TECHE		SHC LEAD BROKEN	REPAIRED	201100610604
5/10/2011	327-021		700	N ROBERTSON	ST PETER	SMH - COVER BROKEN/I	REPLACED	201100616403
8/7/2011			2982	TOLEDANO	S ROMAN	SHC LEAD BROKEN	REPAIRED	201100616802
4/17/2011			3201	FELICIANA	BENEFIT	SHC LEAD BROKEN	REPAIRED	201100623602
4/21/2011			1712-14	FERN	GREEN	SHC LEAD BROKEN	EXCAVATED	201100684402
4/25/2011			1712-14	FERN	GREEN	SHC LEAD BROKEN	REPAIRED	201100684404
4/23/2011	000-000	000-000	738	ARABELLA	MAGAZINE	SEWER MAIN BROKEN	EXCAVATED	201100704103
4/24/2011	000-000	000-000	738	ARABELLA	MAGAZINE	SEWER MAIN BROKEN	REPAIRED	201100704104
5/20/2011				S SARATOGA	TOLEDANO	SHC LEAD BROKEN	REPAIRED	201100712002
5/5/2011			420-22	S JEFFERSON DAV	BANKS	SHC LEAD BROKEN	REPAIRED	201100715502
4/28/2011			1712	LOUISA		SHC LEAD BROKEN	REPAIRED	201100726001
5/31/2011			4811	ANNETTE	MIRABEAU AV	SHC LEAD BROKEN	REPAIRED	201100737601
5/2/2011			5600	LAFAYE	MENDEZ	SHC - BACKUP	REPAIRED	201100741502

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
8/12/2011	125-010	125-009	2833	CONSTANCE	6TH	SHC LEAD BROKEN	EXCAVATED	201100758302
8/15/2011	125-010	125-009	2833	CONSTANCE	6TH	SHC LEAD BROKEN	EXCAVATED	201100758303
8/16/2011	125-010	125-009	2833	CONSTANCE	6TH	SHC LEAD BROKEN	EXCAVATED	201100758305
5/3/2011	0	0	N/A	TENNESSEE	FLORIDA AV	SEWER LEAK - FORCE M	REPAIRED	201100758901
5/13/2011	246-006		1516	GARDENA DR	PERLITA	SMH - BELOW GRADE	REPAIRED	2011007604
5/5/2011			4913-15	ST ANTHONY AV	MIRABEAU AV	SHC LEAD BROKEN	REPAIRED	201100766502
5/9/2011	025-005	-006	2622	GEN OGDEN	APPLE	SHC LEAD BROKEN	REPAIRED	201100768402
8/8/2011	115-028	-026	1908	FOUCHER	DANNEEL	SHC LEAD BROKEN	REPAIRED	201100781102
5/26/2011			7913	COHN	FERN	SHC LEAD BROKEN	REPAIRED	201100782203
5/10/2011			4850	GALAHAD DR	DWYER RD	SHC LEAD BROKEN	REPAIRED	201100782503
5/26/2011			4535	CAMP	CADIZ	SHC LEAD BROKEN	EXCAVATED	201100783501
6/1/2011			4535	CAMP	CADIZ	SHC LEAD BROKEN	REPLACED	201100783502
6/4/2011	459-031	459-028		WALES	TARPON	SEWER MAIN BROKEN	REPAIRED	201100802203

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
5/24/2011	099-014	099-012	4930	S JOHNSON	ROBERT	SHC LEAD BROKEN	REPAIRED	201100816002
5/19/2011	453-011	453-004	6021	BURGUNDY	TOULOUSE	SEWER MAIN BROKEN	REPAIRED	201100820206
5/20/2011	453-011	453-004	6021	BURGUNDY	TOULOUSE	SEWER MAIN BROKEN	REPAIRED	201100820207
5/16/2011			6021	BURGUNDY	TOULOUSE	SHC LEAD BROKEN	EXCAVATED	201100820202
5/17/2011			6021	BURGUNDY	TOULOUSE	SHC LEAD BROKEN	REPAIRED	201100820204
5/18/2011			6021	BURGUNDY	TOULOUSE	SHC LEAD BROKEN	REPAIRED	201100820205
9/27/2011			2228	GEN TAYLOR	S LIBERTY	SHC LEAD BROKEN	EXCAVATED	201100824603
6/2/2011			1118	CASA CALVO	GEN MEYER AV	SHC LEAD BROKEN	REPAIRED	201100831802
5/18/2011			19	ISLAND CLUB DR	ENGLISH TURN DR	SHC LEAD BROKEN	EXCAVATED	201100838702
5/20/2011			19	ISLAND CLUB DR	ENGLISH TURN DR	SHC LEAD BROKEN	EXCAVATED	201100838703
5/23/2011			19	ISLAND CLUB DR	ENGLISH TURN DR	SHC LEAD BROKEN	REPAIRED	201100838705
6/2/2011			7915	GREEN	SHORT	SHC - INSTALL NEW FR(	EXCAVATED	201100844101
5/18/2011	204-010	204-009	3835	IBERVILLE	N SCOTT	SEWER MAIN BROKEN	EXCAVATED	201100846501

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
5/19/2011	204-010	204-009	3835	IBERVILLE	N SCOTT	SEWER MAIN BROKEN	REPAIRED	201100846502
5/18/2011	496-003	496-001	8118	CHEF MENTEUR H	DODT AV	SEWER LEAK - FORCE M	REPAIRED	201100847301
5/20/2011			2343	PRYTANIA	1ST	SHC LEAD BROKEN	REPLACED	201100850702
5/20/2011	148-018		928	FELICITY	CONSTANCE	SMH - BRICK REPAIR OF	REPAIRED	201100854101
5/18/2011	475-038		4964	CHRYSLER	VIENNA	SMH - BRICK REPAIR OF	REPAIRED	201100854301
6/5/2011	410-027			DESIRE PK	BETTY PARKER PL	SMH - BRICK REPAIR OF	REPAIRED	201100855101
5/23/2011			2701	PENISTON	MAGNOLIA	SHC LEAD BROKEN	REPAIRED	201100856902
5/27/2011	109-020	-023	3607	DELACHAISE	S GALVEZ	SHC LEAD BROKEN	EXCAVATED	201100860002
5/31/2011		-023	3607	DELACHAISE	S MIRO	SHC LEAD BROKEN	REPLACED	201100860003
6/29/2011	507-007	507-006	7152	E TAMARON BL		SHC - RELOCATE EXIST	EXCAVATED	201100860504
8/2/2011			7152	E TAMARON BL		SHC LEAD BROKEN	REPAIRED	201100860508
6/5/2011	351-005	351-004	2490	VERBENA	IRIS	SEWER MAIN BROKEN	REPAIRED	201100862002
5/30/2011	285-023		N/A	GOV NICHOLLS	N ROBERTSON	SMH - ABOVE GRADE	REPAIRED	201100877401

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
5/25/2011			3401	MEMORIAL PARK	GARDEN OAKS DR	SHC LEAD BROKEN	REPAIRED	201100880202
5/25/2011			2516	IBERVILLE	N ROCHEBLAVE	SHC LEAD BROKEN	EXCAVATED	201100884801
5/26/2011			2516	IBERVILLE	N ROCHEBLAVE	SHC LEAD BROKEN	REPAIRED	201100884802
6/7/2011			7001	CANAL BL	WALKER	SHC LEAD BROKEN	EXCAVATED	201100894602
6/8/2011			7001	CANAL BL	WALKER	SHC LEAD BROKEN	REPAIRED	201100894603
5/27/2011	0		2238	DELACHAISE	S LIBERTY	SHC LEAD BROKEN	EXCAVATED	201100895302
5/31/2011			2238	DELACHAISE	S LIBERTY	SHC LEAD BROKEN	REPLACED	201100895303
6/1/2011	372-019	372-016	5100	LAFAYE		SEWER MAIN BROKEN	EXCAVATED	201100900603
6/2/2011	372-019	372-016	5100	LAFAYE		SEWER MAIN BROKEN	REPAIRED	201100900604
7/19/2011	267-015	267-014	711	BOURBON	ORLEANS AV	SHC LEAD BROKEN	REPAIRED	201100909904
7/6/2011	173-029	162-018	955	HOWARD AV	DRYADES	SHC LEAD BROKEN	REPAIRED	201100929503
6/15/2011			2651	POYDRAS	S BROAD	SHC LEAD BROKEN	REPAIRED	201100930402
6/5/2011	425-028	425-027	6553	FOCH RD	S LAVERNE	SEWER MAIN BROKEN	EXCAVATED	201100932002

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
6/7/2011	267-027		629	CHARTRES	ST PETER	SMH - COVER BROKEN/I	REPAIRED	201100939001
6/14/2011			3027	HYMAN PL	MACARTHUR BL	SHC LEAD BROKEN	REPAIRED	201100950503
7/20/2011			2613	N VILLERE	PORT	SHC - INSTALL NEW FR(	REPAIRED	201100951601
7/7/2011			200	DE ARMAS	BROOKLYN	SHC LEAD BROKEN	EXCAVATED	201100956402
6/21/2011			3627	HERALD	BERKLEY DR	SHC LEAD BROKEN	REPAIRED	201100958004
6/20/2011	426-008	426-003	4700BLK	BABYLON	PRENTISS AV	SEWER MAIN BROKEN	EXCAVATED	201100960002
6/21/2011	426-008	426-003	4700BLK	BABYLON	PRENTISS AV	SEWER MAIN BROKEN	EXCAVATED	201100960004
8/12/2011	080-018	080-014	1004	JOSEPH	CHESTNUT	SHC LEAD BROKEN	REPLACED	201100960202
6/9/2011	346-023		2477	N MIRO	ARTS	SMH - COVER BROKEN/I	EXCAVATED	201100961401
6/10/2011	346-023		2477	N MIRO	ARTS	SMH - COVER BROKEN/I	REPAIRED	201100961403
6/16/2011	288-036	288-051	2600	ST PHILIP	N DORGENOIS	SHC LEAD BROKEN	REPAIRED	201100971902
6/14/2011	475-027		N/A	PAPANIA DR	DREUX AV	SMH - COVER BROKEN/I	REPLACED	201100974301
6/24/2011			13232	CHEF MENTEUR I	MICHOUD BL	SHC LEAD BROKEN	REPAIRED	201100975804

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
8/8/2011			1813-15	DESIRE	N ROMAN	SHC - INSTALL NEW FR(	EXCAVATED	201100994701
8/9/2011			1813-15	DESIRE	N ROMAN	SHC - INSTALL NEW FR(	REPAIRED	201100994702
6/20/2011			2363	PRANCER	FIESTA	SHC LEAD BROKEN	REPLACED	201100997302
7/19/2011			1633	N PRIEUR	ONZAGA	SHC - INSTALL NEW FR(	REPAIRED	201101004001
6/15/2011			823	N DORGENOIS	DUMAINE	SEE WHY NO WATER	REPAIRED	201101004601
6/15/2011			1217	N ROMAN	GOV NICHOLLS	SEE WHY NO WATER	REPAIRED	201101004701
8/2/2011	306-055	307-001	2708	O"REILLY	PAUL MORPHY	SEWER MAIN BROKEN	REPAIRED	201101008902
6/30/2011			421	BOUNY	ALIX	SHC - INSTALL NEW FR(	EXCAVATED	201101015101
6/18/2011			320	S DUPRE	PALMYRA	SHC LEAD BROKEN	EXCAVATED	201101018002
6/23/2011			320	S DUPRE	PALMYRA	SHC LEAD BROKEN	REPAIRED	201101018003
8/17/2011			946	FRENCH	ARGONNE	SHC LEAD BROKEN	REPAIRED	201101020904
6/27/2011			1133	FARRAGUT	DE ARMAS	SHC LEAD BROKEN	REPAIRED	201101026602
6/28/2011	001-002	001-001	6401	PAINTERS	NEW YORK	SHC LEAD BROKEN	REPAIRED	201101041502

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
9/6/2011	143-042		2100	MAGNOLIA	JOSEPHINE	SMH - BRICK REPAIR OF	REPAIRED	201101048703
10/6/2011	067-044	067-021	520	WEBSTER		SHC LEAD BROKEN	EXCAVATED	201101058102
10/7/2011			520	WEBSTER	LAUREL	SHC LEAD BROKEN	REPAIRED	201101058104
9/26/2011			6722	CATINA	FILMORE AV	SHC LEAD BROKEN	REPAIRED	201101063402
9/13/2011		A26-066	3540	RUE MIGNON	LACOUR MONIQUE	SHC LEAD BROKEN	REPAIRED	201101065404
9/14/2011		A26-066	3540	RUE MIGNON	LACOUR MONIQUE	SHC LEAD BROKEN	REPAIRED	201101065406
7/23/2011			425	CELESTE	S PETERS	SHC - INSTALL NEW FR(	EXCAVATED	201101070001
6/30/2011			3736	HERALD	BERKLEY DR	SHC LEAD BROKEN	EXCAVATED	201101076302
7/3/2011			3736	HERALD	BERKLEY DR	SHC LEAD BROKEN	EXCAVATED	201101076303
8/1/2011			3736	HERALD	BERKLEY DR	SHC LEAD BROKEN	REPAIRED	201101076307
7/22/2011			3736	HERALD	BERKLEY DR	SHC LEAD BROKEN	EXCAVATED	201101076305
7/21/2011			3736	HERALD	BERKLEY DR	SHC LEAD BROKEN	EXCAVATED	201101076304
7/3/2011			6615	LOUIS XIV	FILMORE AV	SHC LEAD BROKEN	REPAIRED	201101085902

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
7/7/2011			3619	HAVANA	ST DENIS	SHC LEAD BROKEN	REPAIRED	201101093202
7/26/2011	473-053	473-052	4637	DONNA DR	GRANT	SHC LEAD BROKEN	REPAIRED	201101094002
7/6/2011			2737	GEN TAYLOR		SHC LEAD BROKEN	EXCAVATED	201101099902
7/5/2011	374-009	374-007	2632	ROBERT E LEE BL	FRANKLIN AV	SEWER MAIN BROKEN	REPAIRED	201101105301
7/30/2011			3232	UPPERLINE	S PRIEUR	SHC LEAD BROKEN	REPAIRED	201101110302
7/23/2011	010-016	010-003	360	LESLIE LN	FLEUR DE LIS DR	SEWER MAIN BROKEN	EXCAVATED	201101111604
8/18/2011	010-016	010-003	360	LESLIE LN	FLEUR DE LIS DR	SEWER MAIN BROKEN	REPAIRED	201101111605
8/2/2011			2022	AUDUBON	SPRUCE	SHC LEAD BROKEN	REPLACED	201101115902
7/12/2011			1019	1ST	MAGAZINE	SHC LEAD BROKEN	EXCAVATED	201101118903
7/13/2011			1019	1ST	MAGAZINE	SHC LEAD BROKEN	EXCAVATED	201101118904
7/9/2011			9233	DWYER RD	BUNDY RD	SHC LEAD BROKEN	REPAIRED	201101119601
7/15/2011	178-049	177-003	517	GRAVIER	MAGAZINE	SHC LEAD BROKEN	REPAIRED	201101120702
7/16/2011	178-049	177-003	517	GRAVIER	MAGAZINE	SHC LEAD BROKEN	REPAIRED	201101120703

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
7/11/2011			2316	WASHINGTON AV		SHC LEAD BROKEN	REPAIRED	201101123702
5/14/2011			625	ST JOSEPH	ST CHARLES AV	SHC LEAD BROKEN	REPAIRED	201101125701
7/20/2011			9320	OLIVE	CHERRY	SHC LEAD BROKEN	REPAIRED	201101133001
9/29/2011			2805	JOSEPHINE	CLARA	SHC LEAD BROKEN	REPAIRED	201101136702
7/13/2011			1114-16	N JOHNSON	URSULINES AV	SHC LEAD BROKEN	REPAIRED	201101142002
9/28/2011			3317	4TH		SHC LEAD BROKEN	REPAIRED	201101147802
8/8/2011			2600	ORLEANS	N DORGENOIS	SHC - INSTALL NEW FR(	EXCAVATED	201101154101
8/16/2011			1725-27	FRANCE	N DERBIGNY	SHC - INSTALL NEW FR(	REPAIRED	201101154601
7/20/2011			1406	LAHARPE		SHC LEAD BROKEN	EXCAVATED	201101178102
7/20/2011			3442	ST CHARLES AV	DELACHAISE	SHC LEAD BROKEN	REPAIRED	201101183602
7/22/2011			4326	SEMINARY PL	MIRABEAU AV	SHC LEAD BROKEN	EXCAVATED	201101191204
7/25/2011			4326	SEMINARY PL	MIRABEAU AV	SHC LEAD BROKEN	REPAIRED	201101191205
9/29/2011	221-032	220-041		COLBERT	POLK AV	SEWER MAIN BROKEN	REPAIRED	201101192701

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
10/5/2011	221-032	220-041		COLBERT	POLK AV	SEWER MAIN BROKEN	REPAIRED	201101192801
10/6/2011	221-032	220-041		COLBERT	POLK AV	SEWER MAIN BROKEN	REPAIRED	201101192901
10/12/2011	222-020	222-018		HARRISON AV	LOUISVILLE	SEWER MAIN BROKEN	REPAIRED	201101193401
7/21/2011			421	BOUNY	PELICAN	SHC LEAD BROKEN	EXCAVATED	201101197201
7/22/2011	309-026		2328	NEW ORLEANS	N TONTI	SHC LEAD BROKEN	REPAIRED	201101199102
7/23/2011			3442	ST CHARLES AV	DELACHAISE	SHC - BACKUP	REPAIRED	201101203201
7/29/2011			3442	ST CHARLES AV	DELACHAISE	SHC LEAD BROKEN	REPAIRED	201101203204
7/26/2011			3442	ST CHARLES AV	DELACHAISE	SHC LEAD BROKEN	EXCAVATED	201101203202
7/23/2011			6356	MILNE BL		SHC LEAD BROKEN	REPAIRED	201101204301
7/25/2011			1717	EGANIA	N ROMAN	SHC LEAD BROKEN	EXCAVATED	201101205002
7/26/2011			2716	MISTLETOE	BELFAST	SHC LEAD BROKEN	EXCAVATED	201101217702
8/8/2011			2716	MISTLETOE	BELFAST	SHC LEAD BROKEN	REPAIRED	201101217704
7/28/2011			2701	ARTS	INDUSTRY	SHC LEAD BROKEN	EXCAVATED	201101225502

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
8/4/2011			2701	ARTS	INDUSTRY	SHC LEAD BROKEN	REPAIRED	201101225503
8/8/2011			9225	PALM	MISTLETOE	SHC - BACKUP	REPAIRED	201101230401
8/11/2011			9225	PALM	MISTLETOE	SHC LEAD BROKEN	REPAIRED	201101230406
8/10/2011			9225	PALM	MISTLETOE	SHC LEAD BROKEN	EXCAVATED	201101230404
8/9/2011			9225	PALM	MISTLETOE	SHC LEAD BROKEN	EXCAVATED	201101230402
8/11/2011			5822	PAULINE DR	PRENTISS AV	SHC LEAD BROKEN	REPAIRED	201101233004
8/2/2011	311-003	311-001	1810	HOPE	REPUBLIC	SEWER MAIN BROKEN	REPAIRED	201101238403
8/9/2011	465-008		4500	VIOLA	GRANT	SMH - COVER BROKEN/I	REPAIRED	201101239901
9/9/2011			1008	DUBLIN	FRERET	SHC LEAD BROKEN	EXCAVATED	201101245102
8/2/2011	305-003		2137	D"ABADIE	N MIRO	SHC LEAD BROKEN	EXCAVATED	201101249402
8/3/2011	305-003		2137	D"ABADIE	N MIRO	SHC LEAD BROKEN	REPAIRED	201101249403
8/15/2011			2140	N ROCHEBLAVE	TOURO	SHC LEAD BROKEN	REPAIRED	201101252203
9/8/2011			4845	CAMP	UPPERLINE	SHC - INSTALL NEW FR(	EXCAVATED	201101254902

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
9/9/2011			4845	CAMP	UPPERLINE	SHC - INSTALL NEW FR(	EXCAVATED	201101254904
8/3/2011			2837	BERKLEY DR	WOODLAND	SHC LEAD BROKEN	REPAIRED	201101255702
8/5/2011			5837	BERKLEY DR	WOODLAND	SHC LEAD BROKEN	REPAIRED	201101255706
8/9/2011			5837	BERKLEY DR	WOODLAND	SHC LEAD BROKEN	REPAIRED	201101255709
8/10/2011			5837	BERKLEY DR	WOODLAND	SHC LEAD BROKEN	REPAIRED	201101255710
8/8/2011			5837	BERKLEY DR	WOODLAND	SHC LEAD BROKEN	EXCAVATED	201101255708
8/4/2011			5837	BERKLEY DR	WOODLAND	SHC LEAD BROKEN	EXCAVATED	201101255703
8/22/2011	226-058		309	OPAL	CAMEO	SMH - COVER BROKEN/I	EXCAVATED	201101260101
9/6/2011	226-058		309	OPAL	CAMEO	SMH - COVER BROKEN/I	REPAIRED	201101260103
8/7/2011	356-037	356-038		MITHRA	SPAIN	SEWER MAIN BROKEN	REPAIRED	201101261301
8/12/2011	266-019		N/A	DECATUR	MADISON	SMH - ABOVE GRADE	REPLACED	201101275401
8/7/2011	143-033	143-032	2912	ST ANDREW	S CLAIBORNE AV	SEWER MAIN BROKEN	REPAIRED	201101278203
8/25/2011			5163	LAFAYE	SELMA	SHC LEAD BROKEN	EXCAVATED	201101280502

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
8/26/2011			5163	LAFAYE	SELMA	SHC LEAD BROKEN	REPAIRED	201101280504
9/15/2011	297-007	297-006	3701	ALFRED	ST DENIS	SHC LEAD BROKEN	REPAIRED	201101284203
8/17/2011			2132	LIZARDI	N MIRO	SHC - INSTALL NEW FR(	EXCAVATED	201101285601
9/7/2011	250-109		4100BLK	PRENTISS AV	CAMPUS BL	SMH - BRICK REPAIR OF	EXCAVATED	201101287102
8/10/2011	0	0	5692	ORLEANS AV	FLORIDA AV	SEWER MAIN BROKEN	REPAIRED	201101294302
8/10/2011	073-029	073-026	2934	PALMER AV	S CLAIBORNE AV	SEWER MAIN BROKEN	REPLACED	201101296003
9/26/2011			156	PELICAN	BOUNY	SHC LEAD BROKEN	REPAIRED	201101303602
8/30/2011	508-048	508-047	8011	BUFFALO RD		SEWER MAIN BROKEN	REPAIRED	201101310402
8/16/2011			5300	ST ANTHONY AV	FILMORE AV	SHC LEAD BROKEN	REPAIRED	201101311302
8/13/2011	132-015	132-014	2701	S MIRO	4TH	SHC LEAD BROKEN	REPAIRED	201101316103
8/12/2011			2701	S MIRO	4TH	SHC LEAD BROKEN	EXCAVATED	201101316102
8/30/2011	026-035	026-034	8533	PRITCHARD PL	LEONIDAS	SEWER MAIN BROKEN	EXCAVATED	201101321104
8/15/2011			416	S JEFFERSON DAV	BANKS	SHC LEAD BROKEN	REPAIRED	201101322802

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
8/16/2011			416	S JEFFERSON DAV	BANKS	SHC LEAD BROKEN	REPAIRED	201101322803
8/29/2011	543-005	543-004	7621	EXPEDITION DR	MICHOUD BL	SHC LEAD BROKEN	REPAIRED	201101336102
8/16/2011			7111-13	BOSTON DR	MIDDLEBORO RD	SHC LEAD BROKEN	EXCAVATED	201101338702
8/19/2011			7111-13	BOSTON DR	MIDDLEBORO RD	SHC LEAD BROKEN	REPAIRED	201101338705
8/18/2011			7111-13	BOSTON DR	MIDDLEBORO RD	SHC LEAD BROKEN	EXCAVATED	201101338704
9/2/2011			5726	ROSEMARY PL	FLORIDA AV	SHC LEAD BROKEN	REPAIRED	201101344502
8/31/2011	196-010		706	CANAL	ST CHARLES AV	SHC LEAD BROKEN	EXCAVATED	201101350405
9/2/2011	196-010		706	CANAL	ST CHARLES AV	SHC LEAD BROKEN	EXCAVATED	201101350407
9/1/2011	196-010		706	CANAL	ST CHARLES AV	SHC LEAD BROKEN	EXCAVATED	201101350406
9/2/2011	196-010		706	CANAL	ST CHARLES AV	SHC LEAD BROKEN	REPAIRED	201101350408
8/26/2011			4644	CAMELOT DR	GRANT	SHC LEAD BROKEN	EXCAVATED	201101352402
8/29/2011			863	OLGA	DUMAINE	SHC LEAD BROKEN	REPAIRED	201101355802
8/26/2011			604	PARK BL	PTOLEMY	SHC LEAD BROKEN	EXCAVATED	201101364702

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
8/29/2011			604	PARK BL	PTOLEMY	SHC LEAD BROKEN	EXCAVATED	201101364704
8/23/2011	381-021	381-20	3162	CHARTRES	LOUISA	SHC LEAD BROKEN	EXCAVATED	201101373902
8/24/2011	381-021	381-20	3162	CHARTRES	LOUISA	SHC LEAD BROKEN	REPAIRED	201101373903
10/17/2011	134-023	134-076	1401	S RENDON		SMH - COVER BROKEN/I	REPLACED	201101384401
8/31/2011			5231	ST CHARLES AV	VALMONT	SHC LEAD BROKEN	REPAIRED	201101384903
8/25/2011	491-076	491-077	9801	E WHEATON CI	WEAVER AV	SHC LEAD BROKEN	REPAIRED	201101394002
8/26/2011			8200	PRITCHARD PL	DUBLIN	SHC LEAD BROKEN	REPAIRED	201101410602
10/22/2011	443-070	443-069		CAFFIN AV	N CLAIBORNE AV	SEWER MAIN BROKEN	REPAIRED	201101413301
10/22/2011	443-070	443-069		CAFFIN AV	N CLAIBORNE AV	SEWER MAIN BROKEN	REPAIRED	201101413401
10/13/2011	444-040	444-039		N JOHNSON	CHOCTAW	SHC LEAD BROKEN	REPAIRED	201101413501
10/2/2011	444-044	444-043		CAFFIN AV	N PRIEUR	SHC LEAD BROKEN	REPAIRED	201101414001
10/4/2011	444-044	444-043		CAFFIN AV	N PRIEUR	SHC LEAD BROKEN	REPAIRED	201101414101
10/12/2011	444-046	444-045		N PRIEUR	CAFFIN AV	SHC LEAD BROKEN	REPAIRED	201101414401

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
10/15/2011	444-046	444-045		N PRIEUR	CAFFIN AV	SEWER MAIN BROKEN	REPAIRED	201101414502
10/15/2011	444-046	444-045		N PRIEUR	CAFFIN AV	SHC LEAD BROKEN	REPAIRED	201101414501
10/16/2011	444-046	444-045		N PRIEUR	CAFFIN AV	SHC LEAD BROKEN	REPAIRED	201101414601
10/16/2011	444-046	444-045		N PRIEUR	CAFFIN AV	SEWER MAIN BROKEN	REPAIRED	201101414701
10/10/2011	444-047	444-046		CAFFIN AV	N ROMAN	SHC LEAD BROKEN	REPAIRED	201101414801
10/10/2011	444-047	444-046		CAFFIN AV	N ROMAN	SHC LEAD BROKEN	REPAIRED	201101414901
10/11/2011	444-047	444-046		CAFFIN AV	N ROMAN	SHC LEAD BROKEN	REPAIRED	201101415001
10/2/2011	444-063	449-006		N MIRO	CAFFIN AV	SHC LEAD BROKEN	REPAIRED	201101415101
10/2/2011	444-063	449-006		N MIRO	CAFFIN AV	SHC LEAD BROKEN	REPAIRED	201101415102
10/2/2011	444-063	449-006		N MIRO	CAFFIN AV	SHC LEAD BROKEN	REPAIRED	201101415201
10/1/2011	445-032	445-031		CAFFIN AV	N ROCHEBLAVE	SEWER MAIN BROKEN	REPAIRED	201101415301
10/2/2011	445-032	445-031		CAFFIN AV	N ROCHEBLAVE	SEWER MAIN BROKEN	REPAIRED	201101415401
10/2/2011	445-032	445-031		CAFFIN AV	N ROCHEBLAVE	SEWER MAIN BROKEN	REPAIRED	201101415601

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
10/16/2011	445-056	450-037		N DORGENOIS	CAFFIN AV	SEWER MAIN BROKEN	REPAIRED	201101415701
10/15/2011	445-056	450-037		N DORGENOIS	CAFFIN AV	SEWER MAIN BROKEN	REPAIRED	201101415801
10/15/2011	445-056	450-037		N DORGENOIS	CAFFIN AV	SHC LEAD BROKEN	REPAIRED	201101415802
10/16/2011	445-056	450-037		N DORGENOIS	CAFFIN AV	SEWER MAIN BROKEN	REPLACED	201101415901
10/8/2011	446-012	445-048		FLOOD	FLORIDA AV	SHC LEAD BROKEN	REPAIRED	201101416101
10/9/2011	446-012	445-048		FLOOD	FLORIDA AV	SHC LEAD BROKEN	REPAIRED	201101416201
10/8/2011	446-012	445-048		FLOOD	FLORIDA AV	SHC LEAD BROKEN	REPAIRED	201101416301
10/8/2011	446-012	445-048		FLOOD	FLORIDA AV	SEWER MAIN BROKEN	REPAIRED	201101416401
10/11/2011	446-013	446-012		FLORIDA AV	CHOCTAW	SHC LEAD BROKEN	REPAIRED	201101416601
10/12/2011	448-043	448-041		BENTON	N DERBIGNY	SHC LEAD BROKEN	REPAIRED	201101416801
10/11/2011	448-043	448-041		BENTON	N DERBIGNY	SEWER MAIN BROKEN	REPAIRED	201101416901
10/11/2011	448-043	448-041		BENTON	N DERBIGNY	SHC LEAD BROKEN	REPAIRED	201101416902
10/11/2011	448-043	448-041		BENTON	N DERBIGNY	SEWER MAIN BROKEN	REPAIRED	201101417001

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
10/8/2011	449-013	449-008		CHARBONNET	N JOHNSON	SEWER MAIN BROKEN	REPAIRED	201101417201
10/8/2011	449-013	449-008		CHARBONNET	N JOHNSON	SEWER MAIN BROKEN	REPAIRED	201101417301
10/9/2011	449-013	449-008		CHARBONNET	N JOHNSON	SHC LEAD BROKEN	REPAIRED	201101417401
10/20/2011	449-017	449-016		ALABO	N PRIEUR	SEWER MAIN BROKEN	REPAIRED	201101417501
10/21/2011	449-017	449-016		ALABO	N PRIEUR	SEWER MAIN BROKEN	REPAIRED	201101417601
10/21/2011	449-017	449-016		ALABO	N PRIEUR	SHC LEAD BROKEN	REPAIRED	201101417701
10/20/2011	449-017	449-016		ALABO	N PRIEUR	SHC LEAD BROKEN	REPAIRED	201101417801
10/20/2011	449-017	449-016		ALABO	N PRIEUR	SHC LEAD BROKEN	REPAIRED	201101418001
10/21/2011	449-017	449-016		ALABO	N PRIEUR	SHC LEAD BROKEN	REPAIRED	201101418101
10/8/2011	449-018	449-013		CHARBONNET	N PRIEUR	SHC LEAD BROKEN	REPAIRED	201101418201
10/13/2011	449-024	449-023		BENTON	N GALVEZ	SHC LEAD BROKEN	REPAIRED	201101418301
10/13/2011	449-024	449-023		BENTON	N GALVEZ	SHC LEAD BROKEN	REPAIRED	201101418501
10/16/2011	449-024	449-023		BENTON	N GALVEZ	SHC LEAD BROKEN	REPAIRED	201101418601

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
10/16/2011	449-024	449-023		BENTON	N GALVEZ	SEWER MAIN BROKEN	REPAIRED	201101418701
10/14/2011	449-031	449-029		BENTON	N PRIEUR	SEWER MAIN BROKEN	REPAIRED	201101418801
10/17/2011	449-031	449-029		BENTON	N PRIEUR	SHC LEAD BROKEN	REPAIRED	201101418802
10/14/2011	449-031	449-029		BENTON	N PRIEUR	SHC LEAD BROKEN	REPAIRED	201101418901
10/17/2011	449-031	449-029		BENTON	N PRIEUR	SHC LEAD BROKEN	REPAIRED	201101419001
10/18/2011	449-032	456-037		N PRIEUR	BENTON	SHC LEAD BROKEN	REPAIRED	201101419201
10/15/2011	449-032	456-037		N PRIEUR	BENTON	SHC LEAD BROKEN	REPAIRED	201101419301
10/18/2011	449-032	456-037		N PRIEUR	BENTON	SEWER MAIN BROKEN	REPAIRED	201101419401
10/15/2011	450-013	450-011		ROFFIGNAC	WHIPPLE	SHC LEAD BROKEN	REPLACED	201101419501
10/16/2011	450-013	450-011		ROFFIGNAC	WHIPPLE	SHC LEAD BROKEN	REPAIRED	201101419601
10/16/2011	450-013	450-011		ROFFIGNAC	WHIPPLE	SHC LEAD BROKEN	REPAIRED	201101419701
10/10/2011	450-019	450-017		WINTHROP	N ROCHEBLAVE	SHC LEAD BROKEN	REPAIRED	201101419801
10/16/2011	450-019	450-017		WINTHROP	N ROCHEBLAVE	SHC LEAD BROKEN	REPAIRED	201101419901

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
10/16/2011	450-019	450-017		WINTHROP	N ROCHEBLAVE	SHC LEAD BROKEN	REPAIRED	201101420001
10/16/2011	450-019	450-017		WINTHROP	N ROCHEBLAVE	SHC LEAD BROKEN	REPAIRED	201101420003
10/15/2011	450-019	450-017		WINTHROP	N ROCHEBLAVE	SEWER MAIN BROKEN	REPAIRED	201101420201
10/8/2011	450-035	450-034		LAMANCHE	N MIRO	SEWER MAIN BROKEN	REPAIRED	201101420301
10/9/2011	450-035	450-034		LAMANCHE	N MIRO	SEWER MAIN BROKEN	REPAIRED	201101420401
10/9/2011	450-035	450-034		LAMANCHE	N MIRO	SHC LEAD BROKEN	REPLACED	201101420601
10/6/2011	451-004	451-003		FLORIDA AV	ALABO	SEWER MAIN BROKEN	REPAIRED	201101420701
10/6/2011	451-004	451-003		FLORIDA AV	ALABO	SHC LEAD BROKEN	REPAIRED	201101420801
10/8/2011	451-007	450-033		CHARBONNET	FLORIDA AV	SHC LEAD BROKEN	REPAIRED	201101420901
10/9/2011	451-007	450-033		CHARBONNET	FLORIDA AV	SHC LEAD BROKEN	REPAIRED	201101420902
10/7/2011	451-008	451-007		FLORIDA AV	ALABO	SHC LEAD BROKEN	REPAIRED	201101421101
10/7/2011	451-008	451-007		FLORIDA AV	ALABO	SHC LEAD BROKEN	REPAIRED	201101421103
10/9/2011	451-008	451-007		FLORIDA AV	ALABO	SEWER MAIN BROKEN	REPAIRED	201101421201

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
10/18/2011	451-009	450-038		LAMANCHE	LAW	SHC LEAD BROKEN	REPAIRED	201101421301
10/18/2011	451-009	450-038		LAMANCHE	LAW	SHC LEAD BROKEN	REPAIRED	201101421401
10/19/2011	451-009	450-038		LAMANCHE	LAW	SHC LEAD BROKEN	REPAIRED	201101421501
10/19/2011	451-009	450-038		LAMANCHE	LAW	SHC LEAD BROKEN	REPAIRED	201101421601
10/9/2011	451-009	450-038		LAMANCHE	LAW	SEWER MAIN BROKEN	REPAIRED	201101421701
10/9/2011	451-009	450-038		LAMANCHE	LAW	SHC LEAD BROKEN	REPAIRED	201101421703
10/7/2011	451-012	450-031		ALABO	FLORIDA AV	SHC LEAD BROKEN	REPAIRED	201101421801
10/7/2011	451-012	450-031		ALABO	FLORIDA AV	SHC LEAD BROKEN	REPAIRED	201101421901
10/8/2011	455-048	455-047		N ROMAN	GORDON	SEWER MAIN BROKEN	REPLACED	201101422001
10/9/2011	455-048	455-047		N ROMAN	GORDON	SEWER MAIN BROKEN	REPAIRED	201101422002
10/12/2011	455-048	455-047		N ROMAN	GORDON	SHC LEAD BROKEN	REPAIRED	201101422101
10/20/2011	455-051	455-050		TUPELO	N CLAIBORNE AV	SHC LEAD BROKEN	REPAIRED	201101422201
10/19/2011	455-051	455-050		TUPELO	N CLAIBORNE AV	SHC LEAD BROKEN	EXCAVATED	201101422301

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
10/20/2011	455-051	455-050		TUPELO	N CLAIBORNE AV	SHC LEAD BROKEN	REPAIRED	201101422302
10/19/2011	455-051	455-050		TUPELO	N CLAIBORNE AV	SHC LEAD BROKEN	REPAIRED	201101422401
8/29/2011	036-028	036-023	8200	PRITCHARD PL	LEONIDAS	SEWER MAIN BROKEN	EXCAVATED	201101426701
9/20/2011	456-001	457-006		ST MAURICE AV	N MIRO	SHC LEAD BROKEN	EXCAVATED	201101427501
9/22/2011	456-001	457-006		ST MAURICE AV	N MIRO	SHC LEAD BROKEN	EXCAVATED	201101427503
9/23/2011	456-001	457-006		ST MAURICE AV	N MIRO	SHC LEAD BROKEN	REPAIRED	201101427504
9/21/2011	456-001	457-006		ST MAURICE AV	N MIRO	SHC LEAD BROKEN	EXCAVATED	201101427502
9/15/2011	456-007	456-001		ST MAURICE AV	N GALVEZ	SHC LEAD BROKEN	EXCAVATED	201101427701
9/16/2011	456-007	456-001		ST MAURICE AV	N GALVEZ	SHC LEAD BROKEN	REPAIRED	201101427702
9/20/2011	456-007	456-001		ST MAURICE AV	N GALVEZ	SHC LEAD BROKEN	REPAIRED	201101427705
9/19/2011	456-007	456-001		ST MAURICE AV	N GALVEZ	SHC LEAD BROKEN	REPAIRED	201101427703
9/22/2011	456-023	456-019		N PRIEUR	TRICOU	SHC LEAD BROKEN	EXCAVATED	201101427901
9/23/2011	456-023	456-019		N PRIEUR	TRICOU	SHC LEAD BROKEN	REPAIRED	201101427902

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
9/26/2011	456-023	456-019		N PRIEUR	TRICOU	SHC LEAD BROKEN	REPAIRED	201101428001
9/29/2011	456-023	456-019		N PRIEUR	TRICOU	SHC LEAD BROKEN	REPAIRED	201101428101
9/27/2011	456-023	456-019		N PRIEUR	TRICOU	SEWER MAIN BROKEN	EXCAVATED	201101428201
9/28/2011	456-023	456-019		N PRIEUR	TRICOU	SEWER MAIN BROKEN	REPAIRED	201101428202
9/28/2011	456-023	456-019		N PRIEUR	TRICOU	SHC LEAD BROKEN	REPLACED	201101428204
9/28/2011	456-023	456-019	6215	N PRIEUR	TRICOU	SHC LEAD BROKEN	REPLACED	201101428203
9/19/2011	456-045	456-043		DELERY	VALJEAN	SHC LEAD BROKEN	EXCAVATED	201101428301
9/20/2011	456-045	456-043		DELERY	VALJEAN	SHC LEAD BROKEN	REPAIRED	201101428302
9/20/2011	456-045	456-043		DELERY	VALJEAN	SHC LEAD BROKEN	EXCAVATED	201101428501
9/22/2011	456-045	456-043		DELERY	VALJEAN	SHC LEAD BROKEN	REPAIRED	201101428503
9/21/2011	456-045	456-043		DELERY	VALJEAN	SHC LEAD BROKEN	EXCAVATED	201101428502
9/7/2011	456-047	456-045		DELERY	N JOHNSON	SHC LEAD BROKEN	EXCAVATED	201101428701
9/8/2011	456-047	456-045		DELERY	N JOHNSON	SHC LEAD BROKEN	REPAIRED	201101428702

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
9/12/2011	456-047	456-045		DELERY	N JOHNSON	SHC LEAD BROKEN	EXCAVATED	201101428801
9/13/2011	456-047	456-045		DELERY	N JOHNSON	SHC LEAD BROKEN	REPAIRED	201101428802
9/14/2011	456-047	456-045		DELERY	N JOHNSON	SHC LEAD BROKEN	EXCAVATED	201101428901
9/15/2011	456-047	456-045		DELERY	N JOHNSON	SHC LEAD BROKEN	REPAIRED	201101428902
9/26/2011	457-002	457-001		N TONTI	ST MAURICE AV	SHC LEAD BROKEN	EXCAVATED	201101429101
9/27/2011	457-002	457-001		N TONTI	ST MAURICE AV	SHC LEAD BROKEN	EXCAVATED	201101429102
9/30/2011	457-002	457-001		N TONTI	ST MAURICE AV	SHC LEAD BROKEN	EXCAVATED	201101429201
10/1/2011	457-002	457-001		N TONTI	ST MAURICE AV	SHC LEAD BROKEN	REPAIRED	201101429202
9/28/2011	457-002	457-001		N TONTI	ST MAURICE AV	SEWER MAIN BROKEN	EXCAVATED	201101429301
9/29/2011	457-002	457-001		N TONTI	ST MAURICE AV	SEWER MAIN BROKEN	REPAIRED	201101429302
9/30/2011	457-003	457-002		TUPELO	N MIRO	SHC LEAD BROKEN	EXCAVATED	201101429401
10/2/2011	457-003	457-002	2223	TUPELO	N MIRO	SHC LEAD BROKEN	REPAIRED	201101429403
10/2/2011	457-003	457-002		TUPELO	N MIRO	SHC LEAD BROKEN	REPAIRED	201101429402

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
10/1/2011	457-003	457-002		TUPELO	N MIRO	SHC LEAD BROKEN	EXCAVATED	201101429501
10/2/2011	457-003	457-002		TUPELO	N MIRO	SHC LEAD BROKEN	REPAIRED	201101429502
10/1/2011	457-003	457-002		TUPELO	N MIRO	SHC LEAD BROKEN	REPAIRED	201101429601
10/1/2011	457-003	457-002		TUPELO	N MIRO	SEWER MAIN BROKEN	REPAIRED	201101429701
10/1/2011	457-003	457-002		TUPELO	N MIRO	SEWER MAIN BROKEN	REPAIRED	201101429801
10/1/2011	457-003	457-002		TUPELO	N MIRO	SHC LEAD BROKEN	EXCAVATED	201101429802
10/2/2011	457-003	457-002		TUPELO	N MIRO	SHC LEAD BROKEN	REPAIRED	201101429803
10/1/2011	457-003	457-002		TUPELO	N MIRO	SEWER MAIN BROKEN	REPAIRED	201101429901
9/13/2011	457-007	457-006		ST MAURICE AV	N ROCHEBLAVE	SEWER MAIN BROKEN	EXCAVATED	201101430001
9/14/2011	457-007	457-006		ST MAURICE AV	N ROCHEBLAVE	SEWER MAIN BROKEN	REPAIRED	201101430002
9/6/2011	457-030	457-029		DUBREUIL	N TONTI	SHC LEAD BROKEN	REPAIRED	201101430101
9/6/2011	457-032	457-031		ORIN	DUBREUIL	SHC LEAD BROKEN	EXCAVATED	201101430201
10/21/2011	457-032	457-031		ORIN	DUBREUIL	SHC LEAD BROKEN	REPAIRED	201101430203

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
10/1/2011	457-048	457-046		TUPELO	N TONTI	SEWER MAIN BROKEN	REPAIRED	201101430301
10/1/2011	457-048	457-046		TUPELO	N TONTI	SHC LEAD BROKEN	REPAIRED	201101430302
10/2/2011	457-048	457-046		TUPELO	N TONTI	SEWER MAIN BROKEN	REPAIRED	201101430401
10/2/2011	457-048	457-046	2208	TUPELO	N TONTI	SHC LEAD BROKEN	REPAIRED	201101430402
10/5/2011	457-048	457-046		TUPELO	N TONTI	SHC LEAD BROKEN	REPAIRED	201101430501
10/2/2011	457-049	457-045		GORDON	N ROCHEBLAVE	SHC LEAD BROKEN	EXCAVATED	201101430601
10/3/2011	457-049	457-045		GORDON	N ROCHEBLAVE	SHC LEAD BROKEN	REPAIRED	201101430602
10/4/2011	457-049	457-045		GORDON	N ROCHEBLAVE	SHC LEAD BROKEN	REPAIRED	201101430701
10/4/2011	457-049	457-045		GORDON	N ROCHEBLAVE	SHC LEAD BROKEN	EXCAVATED	201101430801
10/5/2011	457-049	457-045		GORDON	N ROCHEBLAVE	SHC LEAD BROKEN	REPAIRED	201101430802
10/1/2011	457-050	457-049		N ROCHEBLAVE	TUPELO	SEWER MAIN BROKEN	REPAIRED	201101430901
10/3/2011	457-055	457-049		GORDON	N DORGENOIS	SEWER MAIN BROKEN	EXCAVATED	201101431001
10/4/2011	457-055	457-049		GORDON	N DORGENOIS	SEWER MAIN BROKEN	REPAIRED	201101431002

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
10/4/2011	457-055	457-049		GORDON	N DORGENOIS	SHC LEAD BROKEN	REPAIRED	201101431005
10/4/2011	457-055	457-049		GORDON	N DORGENOIS	SHC LEAD BROKEN	REPAIRED	201101431004
9/7/2011	458-007	458-006		FLORIDA AV	TUPELO	SEWER MAIN BROKEN	EXCAVATED	201101431201
9/9/2011	458-007	458-006		FLORIDA AV	TUPELO	SEWER MAIN BROKEN	REPAIRED	201101431204
9/8/2011	458-007	458-006		FLORIDA AV	TUPELO	SEWER MAIN BROKEN	EXCAVATED	201101431203
9/12/2011	458-007	458-006		FLORIDA AV	TUPELO	SEWER MAIN BROKEN	EXCAVATED	201101431401
8/30/2011			4619	S CLAIBORNE AV	UPPERLINE	SHC LEAD BROKEN	REPAIRED	201101437802
10/26/2011			4615	S CLAIBORNE AV		SHC LEAD BROKEN	REPAIRED	201101438302
8/12/2011	073-008	073-010	5500 BLI	S CLAIBORNE AV	JOSEPH	SEWER MAIN BROKEN	REPAIRED	201101442603
9/12/2011			6076	VICKSBURG	GERMAIN	SHC LEAD BROKEN	REPAIRED	201101453702
9/16/2011			2019	MARTIN LUTHER	S RAMPART	SHC - INSTALL NEW FR(	EXCAVATED	201101465601
10/26/2011			2037-39	JOURDAN AV		SHC - INSTALL NEW FR(	REPAIRED	201101467703
11/19/2011			2037-39	JOURDAN AV		SHC - INSTALL NEW FR(	REPAIRED	201101467704

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
9/12/2011			3005-07	IBERVILLE		SHC LEAD BROKEN	REPLACED	201101469801
10/6/2011	272-053	272-054	900	N BROAD	DUMAINE	SHC LEAD BROKEN	EXCAVATED	201101482004
10/10/2011	272-053	272-054	900	N BROAD	DUMAINE	SHC LEAD BROKEN	REPAIRED	201101482005
9/8/2011	233-050	233-049	6450	MARSHALL FOCH	BRAGG	SHC LEAD BROKEN	REPAIRED	201101484902
11/30/2011	373-012	373-007	5500BLK	EADS	ODIN	SEWER MAIN BROKEN	REPAIRED	201101493004
12/1/2011	373-012	373-007	5500BLK	EADS	ODIN	SEWER MAIN BROKEN	EXCAVATED	201101493005
12/2/2011	373-012	373-007	5500BLK	EADS	ODIN	SEWER MAIN BROKEN	EXCAVATED	201101493006
12/3/2011			5500BLK	EADS	ODIN	SHC LEAD BROKEN	EXCAVATED	201101493007
12/6/2011			5500BLK	EADS	ODIN	SHC LEAD BROKEN	REPAIRED	201101493008
9/20/2011	476-056	476-055	11308	KING RICHARD D	PRENTISS AV	SHC LEAD BROKEN	REPAIRED	201101504403
9/12/2011	401-070	401-078	1027-29	ALVAR	ST CLAUDE AV	SHC LEAD BROKEN	REPAIRED	201101507702
9/14/2011	401-070	401-078	1027-29	ALVAR	ST CLAUDE AV	SHC LEAD BROKEN	REPAIRED	201101507707
9/13/2011	401-070	401-078	1027-29	ALVAR	ST CLAUDE AV	SHC LEAD BROKEN	EXCAVATED	201101507705

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
9/13/2011	401-070	401-078	1027-29	ALVAR	ST CLAUDE AV	SHC LEAD BROKEN	EXCAVATED	201101507703
9/12/2011	000-000	000-000	4300	JOURDAN RD	RAIL RD TRACK	SEWER LEAK - FORCE M	REPAIRED	201101509901
9/8/2011	439-P9	439-P8	4200	FLORIDA AV	FRANCE RD	SEWER LEAK - FORCE M	REPAIRED	201101510101
9/19/2011	214-035	214-007	125	CONRAD	CATINA	SHC LEAD BROKEN	EXCAVATED	201101526102
9/9/2011	0	0		FRANCE RD	FLORIDA BL	SEWER LEAK - FORCE M	REPAIRED	201101533301
9/14/2011	116-041			LOUISIANA AV	MAGNOLIA	SMH - COVER BROKEN/I	REPLACED	201101534301
11/22/2011	127-037	127-036	2524	ST CHARLES AV	3RD	SEWER MAIN BROKEN	EXCAVATED	201101537203
11/23/2011	127-037	127-036	2524	ST CHARLES AV	3RD	SEWER MAIN BROKEN	EXCAVATED	201101537204
9/15/2011	526-010		14970	INTRACOASTAL I	INDUSTRIAL PK	SMH - COVER BROKEN/I	REPAIRED	201101550601
11/15/2011			4011	CANAL	N PIERCE	SHC - INSTALL NEW FR(	EXCAVATED	201101552701
9/26/2011			8800	OLIVE	EAGLE	SHC LEAD BROKEN	EXCAVATED	201101561602
9/28/2011			8800	OLIVE	EAGLE	SHC LEAD BROKEN	EXCAVATED	201101561605
9/27/2011			8800	OLIVE	EAGLE	SHC LEAD BROKEN	EXCAVATED	201101561604

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
9/22/2011	321-016	-015	5326	WILDAIR DR	RAPIDES DR	SHC LEAD BROKEN	EXCAVATED	201101565202
9/23/2011			5326	WILDAIR DR	RAPIDES DR	SHC LEAD BROKEN	EXCAVATED	201101565204
9/22/2011			1767	SHIRLEY DR	VESPASIAN BL	SHC LEAD BROKEN	EXCAVATED	201101566602
10/30/2011			57	WARBLER	OZONE PK	SHC - INSTALL NEW FR(	EXCAVATED	201101580102
11/1/2011			57	WARBLER	OZONE PK	SHC - INSTALL NEW FR(	REPAIRED	201101580104
10/7/2011			428	THAYER	ALIX	SHC LEAD BROKEN	EXCAVATED	201101580603
10/13/2011			428	THAYER	ALIX	SHC LEAD BROKEN	REPAIRED	201101580604
11/11/2011	003-006	003-022	9225	PALM	MISTLETOE	SHC LEAD BROKEN	REPAIRED	201101590802
9/25/2011			1324	MOSS	ESPLANADE AV	SHC LEAD BROKEN	REPAIRED	201101592401
9/26/2011	189-037	188-016	2500 BLI	TULANE AV	S ROCHEBLAVE	SEWER MAIN BROKEN	EXCAVATED	201101592705
9/27/2011	189-037	188-016	528	S BROAD	TULANE AV	SEWER MAIN BROKEN	REPAIRED	201101592707
10/31/2011			816	ARABELLA	MAGAZINE	SHC LEAD BROKEN	REPAIRED	201101598102
10/13/2011			134	S DUPRE	CLEVELAND AV	SHC LEAD BROKEN	EXCAVATED	201101599602

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
10/17/2011			134	S DUPRE	CLEVELAND AV	SHC LEAD BROKEN	EXCAVATED	201101599603
10/18/2011			134	S DUPRE	CLEVELAND AV	SHC LEAD BROKEN	REPAIRED	201101599604
10/24/2011	037-021	037-015	3325-27	S CARROLLTON A	FORSHEY	SHC LEAD BROKEN	EXCAVATED	201101611002
10/25/2011	037-021	037-015	3325-27	S CARROLLTON A	FORSHEY	SHC LEAD BROKEN	REPAIRED	201101611004
10/4/2011			4808	CALLIOPE	S GENOIS	SHC LEAD BROKEN	EXCAVATED	201101612602
10/24/2011			3015	NASHVILLE AV	S JOHNSON	SHC LEAD BROKEN	REPAIRED	201101619003
10/13/2011			2232	BARONNE	JACKSON AV	SHC LEAD BROKEN	REPAIRED	201101622502
10/5/2011	413-006	414-015	626	POLAND AV	ROYAL	SHC LEAD BROKEN	EXCAVATED	201101623103
10/5/2011	413-006	414-015	626	POLAND AV	ROYAL	SHC LEAD BROKEN	REPAIRED	201101623104
9/30/2011			2743	ST ANN	N WHITE	SHC LEAD BROKEN	REPAIRED	201101633102
11/1/2011	457-005	456-028		MONTICELLO	N TONTI	SEWER MAIN BROKEN	REPAIRED	201101633701
10/1/2011			5225	EADS	FILMORE	SHC LEAD BROKEN	EXCAVATED	201101638402
10/3/2011			5225	EADS	FILMORE	SHC LEAD BROKEN	REPAIRED	201101638403

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
10/25/2011			2400	MAZANT		SHC LEAD BROKEN	REPAIRED	201101655402
10/4/2011			4007	VENDOME PL	FONTAINEBLEAU DR	SHC LEAD BROKEN	EXCAVATED	201101657602
10/5/2011			4007	VENDOME PL	FONTAINEBLEAU DR	SHC LEAD BROKEN	REPAIRED	201101657603
10/13/2011	250-059		N/A	CAMPUS BL	PRENTISS AV	SMH - BRICK REPAIR OF	REPAIRED	201101660902
10/25/2011			2725	PRANCER	VIXEN	SHC LEAD BROKEN	EXCAVATED	201101672902
10/26/2011			2725	PRANCER	VIXEN	SHC LEAD BROKEN	REPAIRED	201101672904
11/17/2011			6761	VICKSBURG	FILMORE AV	SHC LEAD BROKEN	REPAIRED	201101681502
10/28/2011	523-026		5316	MICHOUD BL	LEMANS	SMH - COVER BROKEN/I	REPLACED	201101682203
10/8/2011			2041	SELMA	TOURO	SHC LEAD BROKEN	EXCAVATED	201101688202
10/13/2011			2508	CLARA	2ND	SHC LEAD BROKEN	EXCAVATED	201101696803
10/14/2011			2508	CLARA	2ND	SHC LEAD BROKEN	REPAIRED	201101696804
10/11/2011			2620	S GALVEZ	3RD	SHC LEAD BROKEN	EXCAVATED	201101706002
10/12/2011			2620	S GALVEZ	3RD	SHC LEAD BROKEN	REPAIRED	201101706004

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
10/14/2011	107-007	107-006	2734	MILAN	CLARA	SHC LEAD BROKEN	REPAIRED	201101726004
10/13/2011			2734	MILAN	CLARA	SHC LEAD BROKEN	EXCAVATED	201101726002
10/14/2011			6007	MILNE BL	POLK	SHC LEAD BROKEN	REPAIRED	201101756601
10/25/2011	443-078	444-027		ANDRY	N PRIEUR	SHC LEAD BROKEN	REPAIRED	201101756901
10/26/2011	443-078	444-027		ANDRY	N PRIEUR	SHC LEAD BROKEN	REPAIRED	201101756902
10/23/2011	443-078	444-027		ANDRY	N PRIEUR	SHC LEAD BROKEN	REPAIRED	201101757001
10/23/2011	443-078	444-027		ANDRY	N PRIEUR	SHC LEAD BROKEN	REPAIRED	201101757101
10/22/2011	443-078	444-027		ANDRY	N PRIEUR	SEWER MAIN BROKEN	REPAIRED	201101757301
10/22/2011	445-003	445-002		REYNES	N ROCHEBLAVE	SHC LEAD BROKEN	REPLACED	201101757501
10/23/2011	445-003	445-002		REYNES	N ROCHEBLAVE	SHC LEAD BROKEN	REPLACED	201101757701
10/23/2011	445-003	445-002		REYNES	N ROCHEBLAVE	SEWER MAIN BROKEN	REPLACED	201101757801
10/24/2011	445-003	445-002		REYNES	N ROCHEBLAVE	SHC LEAD BROKEN	REPAIRED	201101757901
10/22/2011	445-020	445-019		LAW	EGANIA	SHC LEAD BROKEN	REPAIRED	201101758101

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
10/23/2011	445-020	445-019		LAW	EGANIA	SHC LEAD BROKEN	REPAIRED	201101758201
10/23/2011	445-020	445-019		LAW	EGANIA	SHC LEAD BROKEN	REPAIRED	201101758204
10/23/2011	445-020	445-019		LAW	EGANIA	SHC LEAD BROKEN	REPAIRED	201101758205
11/1/2011	445-049	445-021		LAW	CHOCTAW	SHC LEAD BROKEN	REPAIRED	201101758401
11/1/2011	445-049	445-021		LAW	CHOCTAW	SEWER MAIN BROKEN	REPAIRED	201101758601
10/22/2011	446-007	446-006		FLORIDA AV	LIZARDI	SHC LEAD BROKEN	REPAIRED	201101758701
10/22/2011	446-007	446-006		FLORIDA AV	LIZARDI	SHC LEAD BROKEN	REPAIRED	201101758801
10/23/2011	446-007	446-006		FLORIDA AV	LIZARDI	SEWER MAIN BROKEN	REPAIRED	201101758901
10/24/2011	455-022	455-084		TRICOU	N DERBIGNY	SEWER MAIN BROKEN	REPAIRED	201101759001
10/24/2011	455-022	455-084		TRICOU	N DERBIGNY	SEWER MAIN BROKEN	REPAIRED	201101759101
10/26/2011	455-022	455-084		TRICOU	N DERBIGNY	SEWER MAIN BROKEN	REPAIRED	201101759102
10/23/2011	455-045	455-043		DELERY	N DERBIGNY	SHC LEAD BROKEN	REPAIRED	201101759201
10/23/2011	455-045	455-043		DELERY	N DERBIGNY	SHC LEAD BROKEN	REPAIRED	201101759301

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
10/19/2011	0	0		DWYER BL	BULLARD AV	SEWER LEAK - FORCE M	EXCAVATED	201101772001
10/20/2011	0	0		DWYER BL	BULLARD AV	SEWER LEAK - FORCE M	EXCAVATED	201101772002
10/22/2011			3519	CECIL	PALM	SHC LEAD BROKEN	REPAIRED	201101772602
10/19/2011	000-000	000-000	14601	OLD GENTILLY R		SEWER LEAK - FORCE M	EXCAVATED	201101800901
10/28/2011			4014	HOLLYGROVE	PEACH	SHC LEAD BROKEN	REPAIRED	201101809503
12/15/2011	455-022	455-084		TRICOU	N DERBIGNY	SEWER MAIN BROKEN	REPAIRED	201101811602
11/3/2011			2711	PRANCER	VIXEN	SHC LEAD BROKEN	EXCAVATED	201101822901
11/7/2011			2711	PRANCER	VIXEN	SHC LEAD BROKEN	REPAIRED	201101822904
11/9/2011	435-033	435-032		N VILLERE	SISTER	SHC LEAD BROKEN	REPAIRED	201101832001
11/9/2011	435-033	435-032		N VILLERE	SISTER	SHC LEAD BROKEN	REPAIRED	201101832101
11/5/2011	435-040	435-039		DESLONDE	N VILLERE	SHC LEAD BROKEN	REPLACED	201101832201
11/5/2011	435-040	435-039		DESLONDE	N VILLERE	SHC LEAD BROKEN	EXCAVATED	201101832301
11/6/2011	435-040	435-039		DESLONDE	N VILLERE	SHC LEAD BROKEN	REPAIRED	201101832302

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
11/2/2011	435-048	435-047		TENNESSEE	ST CLAUDE AV	SHC LEAD BROKEN	REPAIRED	201101832401
11/2/2011	435-048	435-047		TENNESSEE	ST CLAUDE AV	SHC LEAD BROKEN	REPAIRED	201101832501
12/3/2011	435-057	435-056		ST CLAUDE AV	TENNESSEE	SHC LEAD BROKEN	REPAIRED	201101832601
11/9/2011	435-070	435-042		URQUHART	JOURDAN AV	SHC LEAD BROKEN	REPAIRED	201101832701
11/10/2011	435-070	435-042		URQUHART	JOURDAN AV	SEWER MAIN BROKEN	REPAIRED	201101832801
11/10/2011	435-070	435-042		URQUHART	JOURDAN AV	SEWER MAIN BROKEN	REPAIRED	201101832901
11/6/2011	436-012	436-011		N ROBERTSON	TENNESSEE	SHC LEAD BROKEN	REPAIRED	201101833001
11/5/2011	437-016	437-012		DESLONDE	N PRIEUR	SHC LEAD BROKEN	REPAIRED	201101833101
11/6/2011	437-016	437-012		DESLONDE	N PRIEUR	SEWER MAIN BROKEN	REPAIRED	201101833201
11/6/2011	437-016	437-012		DESLONDE	N PRIEUR	SHC LEAD BROKEN	REPAIRED	201101833204
11/6/2011	442-052	442-051		URQUHART	FLOOD	SHC LEAD BROKEN	REPAIRED	201101833301
11/5/2011	442-052	442-051		URQUHART	FLOOD	SHC LEAD BROKEN	REPAIRED	201101833401
11/3/2011	442-052	442-051		URQUHART	FLOOD	SEWER MAIN BROKEN	REPAIRED	201101833501

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
11/5/2011	442-052	442-051		URQUHART	FLOOD	SEWER MAIN BROKEN	REPAIRED	201101833601
11/6/2011	443-003	443-002		N ROBERTSON	FORSTALL	SHC LEAD BROKEN	REPAIRED	201101833701
11/5/2011	443-003	443-002		N ROBERTSON	FORSTALL	SEWER MAIN BROKEN	REPAIRED	201101833801
11/6/2011	443-003	443-002		N ROBERTSON	FORSTALL	SHC LEAD BROKEN	REPAIRED	201101833804
11/6/2011	443-003	443-002	5006	N ROBERTSON	FORSTALL	SHC LEAD BROKEN	REPAIRED	201101833803
11/6/2011	443-003	443-002		N ROBERTSON	FORSTALL	SHC LEAD BROKEN	REPAIRED	201101833802
11/6/2011	443-009	443-008		FORSTALL	N CLAIBORNE AV	SHC LEAD BROKEN	EXCAVATED	201101834001
11/7/2011	443-009	443-008	1502	FORSTALL	N CLAIBORNE AV	SHC LEAD BROKEN	REPAIRED	201101834002
11/8/2011	443-022	443-020		N ROMAN	EGANIA	SHC LEAD BROKEN	REPAIRED	201101834101
11/8/2011	443-022	443-020		N ROMAN	EGANIA	SEWER MAIN BROKEN	REPAIRED	201101834301
11/3/2011	443-029	443-027		LIZARDI	N CLAIBORNE AV	SHC LEAD BROKEN	REPAIRED	201101834401
11/3/2011	443-029	443-027		LIZARDI	N CLAIBORNE AV	SHC LEAD BROKEN	REPAIRED	201101834601
11/6/2011	443-029	443-027		LIZARDI	N CLAIBORNE AV	SHC LEAD BROKEN	REPLACED	201101834701

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
11/4/2011	443-029	443-027		LIZARDI	N CLAIBORNE AV	SHC LEAD BROKEN	REPAIRED	201101834801
11/4/2011	443-029	443-027		LIZARDI	N CLAIBORNE AV	SEWER MAIN BROKEN	REPAIRED	201101835001
11/12/2011	443-032	443-030		N DERBIGNY	ANDRY	SHC LEAD BROKEN	REPAIRED	201101835201
11/13/2011	443-032	443-030		N DERBIGNY	ANDRY	SHC LEAD BROKEN	REPLACED	201101835301
11/13/2011	443-032	443-030		N DERBIGNY	ANDRY	SHC LEAD BROKEN	REPLACED	201101835303
11/12/2011	443-032	443-030		N DERBIGNY	ANDRY	SHC LEAD BROKEN	REPAIRED	201101835401
11/13/2011	443-032	443-030		N DERBIGNY	ANDRY	SHC LEAD BROKEN	REPAIRED	201101835501
11/18/2011	443-032	443-030		N DERBIGNY	ANDRY	SHC LEAD BROKEN	REPAIRED	201101835601
11/5/2011	443-039	443-037		LIZARDI	N CLAIBORNE AV	SHC LEAD BROKEN	REPLACED	201101835701
11/10/2011	443-043	443-042		N ROBERTSON	ANDRY	SHC LEAD BROKEN	REPAIRED	201101835801
11/10/2011	443-043	443-042		N ROBERTSON	ANDRY	SHC LEAD BROKEN	REPAIRED	201101835901
11/2/2011	443-046	443-045		N ROBERTSON	FLOOD	SEWER MAIN BROKEN	REPAIRED	201101836001
11/2/2011	443-046	443-045		N ROBERTSON	FLOOD	SHC LEAD BROKEN	REPAIRED	201101836101

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
11/15/2011	443-050	443-049		N CLAIBORNE AV	FLOOD	SHC LEAD BROKEN	EXCAVATED	201101836201
11/16/2011	443-050	443-049		N CLAIBORNE AV	FLOOD	SHC LEAD BROKEN	REPAIRED	201101836202
11/7/2011	443-053	443-052		N CLAIBORNE AV	CHOCTAW	SHC LEAD BROKEN	REPAIRED	201101836301
11/9/2011	443-053	443-052		N CLAIBORNE AV	CHOCTAW	SEWER MAIN BROKEN	REPAIRED	201101836401
11/8/2011	443-053	443-052		N CLAIBORNE AV	CHOCTAW	SHC LEAD BROKEN	REPAIRED	201101836501
11/8/2011	443-053	443-052		N CLAIBORNE AV	CHOCTAW	SHC LEAD BROKEN	REPAIRED	201101836701
11/12/2011	444-019	444-017		N JOHNSON	EGANIA	SHC LEAD BROKEN	REPAIRED	201101837001
11/12/2011	444-019	444-017		N JOHNSON	EGANIA	SHC LEAD BROKEN	REPAIRED	201101837201
11/1/2011			2515	MILAN	FRERET	SHC LEAD BROKEN	EXCAVATED	201101854002
11/2/2011			2515	MILAN	FRERET	SHC LEAD BROKEN	REPAIRED	201101854003
11/4/2011	478-059	478-057	9500	HAYNE BL	TRAPIER AV	SEWER MAIN BROKEN	EXCAVATED	201101854204
11/7/2011	478-059	478-057	9500	HAYNE BL	TRAPIER AV	SEWER MAIN BROKEN	REPAIRED	201101854205
11/10/2011			6030	CANAL BL	POLK AV	SHC LEAD BROKEN	REPAIRED	201101863101

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
11/7/2011			1406	LAHARPE	N VILLERE	SHC LEAD BROKEN	EXCAVATED	201101869102
11/9/2011			1406	LAHARPE	N VILLERE	SHC LEAD BROKEN	REPAIRED	201101869105
11/7/2011			1406	LAHARPE	N VILLERE	SHC LEAD BROKEN	REPAIRED	201101869103
11/8/2011			1406	LAHARPE	N VILLERE	SHC LEAD BROKEN	EXCAVATED	201101869104
12/1/2011	444-019	444-017		N JOHNSON	EGANIA	SEWER MAIN BROKEN	REPAIRED	201101880401
11/14/2011	444-020	444-019		N JOHNSON	EGANIA	SHC LEAD BROKEN	REPAIRED	201101880501
11/14/2011	444-020	444-019		N JOHNSON	EGANIA	SHC LEAD BROKEN	REPAIRED	201101880601
11/12/2011	444-058	444-057		N GALVEZ	REYNES	SEWER MAIN BROKEN	EXCAVATED	201101880701
11/28/2011	444-058	444-057		N GALVEZ	REYNES	SEWER MAIN BROKEN	REPAIRED	201101880702
11/12/2011	444-058	444-057		N GALVEZ	REYNES	SEWER MAIN BROKEN	EXCAVATED	201101880801
11/28/2011	444-058	444-057		N GALVEZ	REYNES	SEWER MAIN BROKEN	REPAIRED	201101880802
12/3/2011	448-003	448-002		LAMANCHE	MARAIS	SEWER MAIN BROKEN	REPAIRED	201101880901
12/1/2011	448-003	448-002		LAMANCHE	MARAIS	SHC LEAD BROKEN	REPAIRED	201101881001

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
11/11/2011	448-003	448-002		LAMANCHE	MARAIS	SHC LEAD BROKEN	REPAIRED	201101881101
11/11/2011	448-003	448-002		LAMANCHE	MARAIS	SHC LEAD BROKEN	REPAIRED	201101881201
11/16/2011	448-046	448-045		N CLAIBORNE AV	ALABO	SHC LEAD BROKEN	REPAIRED	201101881301
11/15/2011	448-048	448-047		ALABO	N CLAIBORNE AV	SHC LEAD BROKEN	REPAIRED	201101881401
11/15/2011	454-007	454-006		ST CLAUDE AV	TUPELO	SHC LEAD BROKEN	REPAIRED	201101881501
11/15/2011	454-007	454-006		ST CLAUDE AV	TUPELO	SHC LEAD BROKEN	REPAIRED	201101881601
12/4/2011	454-007	454-006		ST CLAUDE AV	TUPELO	SHC LEAD BROKEN	REPAIRED	201101881701
11/19/2011	454-026	454-025		ST MAURICE AV	ST CLAUDE AV	SHC LEAD BROKEN	REPLACED	201101881801
11/11/2011	454-045	454-043		DELERY	ST CLAUDE AV	SHC LEAD BROKEN	REPAIRED	201101881901
11/11/2011	454-045	454-043		DELERY	ST CLAUDE AV	SEWER MAIN BROKEN	REPAIRED	201101882001
11/18/2011	455-007	455-001		N ROBERTSON	ST MAURICE AV	SHC LEAD BROKEN	REPAIRED	201101882101
11/17/2011	455-007	455-001		N ROBERTSON	ST MAURICE AV	SEWER MAIN BROKEN	REPAIRED	201101882201
12/3/2011	455-033	455-032		N CLAIBORNE AV	TUPELO	SHC LEAD BROKEN	REPAIRED	201101882301

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
12/3/2011	455-033	455-032		N CLAIBORNE AV	TUPELO	SHC LEAD BROKEN	REPAIRED	201101882401
12/3/2011	435-066	435-065		ST CLAUDE AV	TENNESSEE	SHC LEAD BROKEN	REPLACED	201101891301
12/4/2011	435-066	435-065		ST CLAUDE AV	TENNESSEE	SEWER MAIN BROKEN	REPAIRED	201101891401
11/29/2011	435-069	434-004		JOURDAN AV	ST CLAUDE AV	SHC LEAD BROKEN	REPAIRED	201101891701
11/30/2011	435-069	434-004		JOURDAN AV	ST CLAUDE AV	SEWER MAIN BROKEN	REPAIRED	201101891801
11/29/2011	435-069	434-004		JOURDAN AV	ST CLAUDE AV	SEWER MAIN BROKEN	REPAIRED	201101891901
11/17/2011	436-004	436-003		N CLAIBORNE AV	JOURDAN AV	SEWER MAIN BROKEN	REPAIRED	201101892101
11/16/2011	436-004	436-003		N CLAIBORNE AV	JOURDAN AV	SHC LEAD BROKEN	REPAIRED	201101892201
12/4/2011	436-030	436-029		N DERBIGNY	DESLONDE	SHC LEAD BROKEN	REPAIRED	201101892301
12/5/2011	441-012	441-010		EGANIA	DAUPHINE	SEWER MAIN BROKEN	EXCAVATED	201101892401
12/8/2011	441-012	441-010		EGANIA	DAUPHINE	SEWER MAIN BROKEN	REPAIRED	201101892404
12/7/2011	441-012	441-010		EGANIA	DAUPHINE	SEWER MAIN BROKEN	REPAIRED	201101892403
12/6/2011	441-012	441-010		EGANIA	DAUPHINE	SEWER MAIN BROKEN	REPAIRED	201101892402

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
11/19/2011	441-012	441-010		EGANIA	DAUPHINE	SEWER MAIN BROKEN	REPLACED	201101892501
11/20/2011	441-012	441-010	5301	EGANIA	DAUPHINE	SHC LEAD BROKEN	REPAIRED	201101892504
11/20/2011	441-012	441-010		EGANIA	DAUPHINE	SHC LEAD BROKEN	REPLACED	201101892503
11/21/2011	441-012	441-010		EGANIA	DAUPHINE	SEWER MAIN BROKEN	REPAIRED	201101892601
11/22/2011	441-012	441-010		EGANIA	DAUPHINE	SEWER MAIN BROKEN	REPAIRED	201101892602
12/12/2011	441-012	441-010		EGANIA	DAUPHINE	SHC LEAD BROKEN	REPAIRED	201101892701
11/19/2011	441-012	441-010		EGANIA	DAUPHINE	SHC LEAD BROKEN	REPAIRED	201101892801
11/19/2011	441-012	441-010		EGANIA	DAUPHINE	SHC LEAD BROKEN	REPAIRED	201101892802
12/9/2011	441-017	441-014		DAUPHINE	FORSTALL	SHC LEAD BROKEN	REPAIRED	201101892901
12/8/2011	441-018	441-017		DAUPHINE	REYNES	SHC LEAD BROKEN	REPAIRED	201101893101
12/9/2011	441-018	441-017		DAUPHINE	REYNES	SHC LEAD BROKEN	REPAIRED	201101893201
11/20/2011	441-027	441-026		ANDRY	N RAMPART	SEWER MAIN BROKEN	REPLACED	201101893301
11/19/2011	441-027	441-026		ANDRY	N RAMPART	SHC LEAD BROKEN	REPAIRED	201101893401

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
11/19/2011	441-027	441-026		ANDRY	N RAMPART	SHC LEAD BROKEN	EXCAVATED	201101893501
11/20/2011	441-027	441-026		ANDRY	N RAMPART	SHC LEAD BROKEN	REPLACED	201101893502
12/3/2011	441-035	441-034		CAFFIN AV	N RAMPART	SHC LEAD BROKEN	EXCAVATED	201101893601
12/4/2011	441-035	441-034		CAFFIN AV	N RAMPART	SHC LEAD BROKEN	REPAIRED	201101893602
12/11/2011	441-035	441-034		CAFFIN AV	N RAMPART	SHC LEAD BROKEN	REPAIRED	201101893701
12/10/2011	441-035	441-034		CAFFIN AV	N RAMPART	SHC LEAD BROKEN	REPAIRED	201101893801
12/3/2011	441-035	441-034		CAFFIN AV	N RAMPART	SHC LEAD BROKEN	REPAIRED	201101893901
12/3/2011	441-035	441-034		CAFFIN AV	N RAMPART	SEWER MAIN BROKEN	REPAIRED	201101894001
12/13/2011	441-038	441-026		ANDRY	DAUPHINE	SEWER MAIN BROKEN	REPAIRED	201101894201
12/11/2011	441-039	441-038		ANDRY	ROYAL	SHC LEAD BROKEN	REPAIRED	201101894301
12/11/2011	441-039	441-038		ANDRY	ROYAL	SHC LEAD BROKEN	REPAIRED	201101894401
12/11/2011	441-039	441-038		ANDRY	ROYAL	SHC LEAD BROKEN	REPAIRED	201101894501
12/11/2011	441-039	441-038		ANDRY	ROYAL	SHC LEAD BROKEN	REPAIRED	201101894601

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
12/10/2011	441-041	441-042		ROYAL	ANDRY	SHC LEAD BROKEN	REPLACED	201101894701
12/10/2011	441-041	441-042		ROYAL	ANDRY	SHC LEAD BROKEN	REPLACED	201101894801
12/10/2011	441-041	441-042		ROYAL	ANDRY	SHC LEAD BROKEN	REPAIRED	201101894901
12/18/2011	441-048	441-047		CAFFIN AV	ROYAL	SHC LEAD BROKEN	REPLACED	201101895601
12/17/2011	441-048	441-047		CAFFIN AV	ROYAL	SHC LEAD BROKEN	REPAIRED	201101895701
12/18/2011	441-048	441-047		CAFFIN AV	ROYAL	SHC LEAD BROKEN	REPAIRED	201101895801
12/17/2011	441-048	441-047		CAFFIN AV	ROYAL	SHC LEAD BROKEN	REPLACED	201101895901
12/28/2011	441-049	441-048		ROYAL	FLOOD	SHC LEAD BROKEN	EXCAVATED	201101896001
12/29/2011	441-049	441-048		ROYAL	FLOOD	SHC LEAD BROKEN	REPAIRED	201101896002
12/20/2011	441-049	441-048		ROYAL	FLOOD	SHC LEAD BROKEN	EXCAVATED	201101896101
12/21/2011	441-049	441-048		ROYAL	FLOOD	SHC LEAD BROKEN	REPAIRED	201101896102
12/19/2011	441-049	441-048		ROYAL	FLOOD	SHC LEAD BROKEN	REPAIRED	201101896201
12/17/2011	442-042	442-041		ST CLAUDE AV	ANDRY	SHC LEAD BROKEN	REPAIRED	201101896301

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
12/18/2011	446-008	446-006		FLORIDA AV	ANDRY	SHC LEAD BROKEN	REPAIRED	201101897501
12/27/2011	447-001	441-034		BURGUNDY	LAMANCHE	SHC LEAD BROKEN	EXCAVATED	201101897601
12/30/2011	447-001	441-034		BURGUNDY	LAMANCHE	SHC LEAD BROKEN	REPAIRED	201101897605
12/28/2011	447-001	441-034		BURGUNDY	LAMANCHE	SHC LEAD BROKEN	EXCAVATED	201101897603
12/29/2011	447-001	441-034		BURGUNDY	LAMANCHE	SHC LEAD BROKEN	EXCAVATED	201101897604
12/17/2011	447-001	441-034		BURGUNDY	LAMANCHE	SEWER MAIN BROKEN	EXCAVATED	201101897701
12/19/2011	447-001	441-034		BURGUNDY	LAMANCHE	SEWER MAIN BROKEN	REPLACED	201101897704
12/18/2011	447-001	441-034		BURGUNDY	LAMANCHE	SEWER MAIN BROKEN	EXCAVATED	201101897702
12/16/2011	447-004	441-047		DAUPHINE	LAMANCHE	SEWER MAIN BROKEN	EXCAVATED	201101897801
12/17/2011	447-004	441-047		DAUPHINE	LAMANCHE	SEWER MAIN BROKEN	REPAIRED	201101897802
12/10/2011	447-005	447-004		LAMANCHE	ROYAL	SHC LEAD BROKEN	REPAIRED	201101897901
12/10/2011	447-005	447-004		LAMANCHE	ROYAL	SHC LEAD BROKEN	REPAIRED	201101898001
12/10/2011	447-005	447-004		LAMANCHE	ROYAL	SHC LEAD BROKEN	REPAIRED	201101898101

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
12/10/2011	447-005	447-004		LAMANCHE	ROYAL	SEWER MAIN BROKEN	REPAIRED	201101898201
12/18/2011	447-006	447-001		BURGUNDY	CHARBONNET	SEWER MAIN BROKEN	EXCAVATED	201101898301
12/19/2011	447-006	447-001		BURGUNDY	CHARBONNET	SEWER MAIN BROKEN	EXCAVATED	201101898303
12/22/2011	447-006	447-001		BURGUNDY	CHARBONNET	SEWER MAIN BROKEN	EXCAVATED	201101898305
12/22/2011	447-006	447-001		BURGUNDY	CHARBONNET	SEWER MAIN BROKEN	REPAIRED	201101898306
12/27/2011	447-006	447-001		BURGUNDY	CHARBONNET	SEWER MAIN BROKEN	EXCAVATED	201101898401
12/30/2011	447-006	447-001		BURGUNDY	CHARBONNET	SEWER MAIN BROKEN	EXCAVATED	201101898403
1/5/2011	447-007	447-006		CHARBONNET	N RAMPART	SHC LEAD BROKEN	REPAIRED	201101898601
12/10/2011	447-010	447-007		N RAMPART	LAMANCHE	SEWER MAIN BROKEN	REPAIRED	201101898901
12/10/2011	447-010	447-007		N RAMPART	LAMANCHE	SEWER MAIN BROKEN	REPAIRED	201101899301
12/11/2011	447-010	447-007		N RAMPART	LAMANCHE	SHC LEAD BROKEN	REPAIRED	201101899401
12/14/2011	447-013	447-012		LAMANCHE	CHARTRES	SEWER MAIN BROKEN	REPAIRED	201101899801
12/15/2011	447-013	447-012		LAMANCHE	CHARTRES	SEWER MAIN BROKEN	REPAIRED	201101899901

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
12/14/2011	447-015	447-014		CHARBONNET	CHARTRES	SHC LEAD BROKEN	REPAIRED	201101900001
12/18/2011	447-017	447-016		LAMANCHE	DOUGLAS	SHC LEAD BROKEN	REPAIRED	201101900201
12/13/2011	447-019	447-016		CHARTRES	CHARBONNET	SEWER MAIN BROKEN	REPAIRED	201101900301
12/13/2011	447-019	447-016		CHARTRES	CHARBONNET	SEWER MAIN BROKEN	REPAIRED	201101900401
12/13/2011	447-019	447-016		CHARTRES	CHARBONNET	SHC LEAD BROKEN	REPAIRED	201101900601
12/16/2011	447-020	447-019		CHARBONNET	CHARTRES	SEWER MAIN BROKEN	REPAIRED	201101900701
11/8/2011	543-001	543-SPSOKI	14101	MICHOUD BL		SEWER LEAK - FORCE M	REPAIRED	201101904803
11/7/2011	543-001		14201	MICHOUD BL		SMH - OVERFLOWING	EXCAVATED	201101904801
11/19/2011	453-036	453-030		DAUPHINE	TRICOU	SEWER MAIN BROKEN	REPAIRED	201101910501
11/20/2011	453-036	453-030		DAUPHINE	TRICOU	SEWER MAIN BROKEN	REPAIRED	201101910601
11/19/2011	453-036	453-030		DAUPHINE	TRICOU	SHC LEAD BROKEN	REPAIRED	201101910701
11/20/2011	453-037	453-036		TRICOU	ROYAL	SEWER MAIN BROKEN	REPAIRED	201101910801
12/7/2011	453-038	453-036		DAUPHINE	DELERY	SHC LEAD BROKEN	REPAIRED	201101910901

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
12/6/2011	453-038	453-036		DAUPHINE	DELERY	SHC LEAD BROKEN	REPAIRED	201101911001
12/7/2011	453-038	453-036		DAUPHINE	DELERY	SHC LEAD BROKEN	REPAIRED	201101911101
12/6/2011	453-038	453-036		DAUPHINE	DELERY	SHC LEAD BROKEN	REPAIRED	201101911201
12/1/2011	453-043	453-039		DELERY	ROYAL	SHC LEAD BROKEN	REPAIRED	201101911401
11/29/2011	453-043	453-039		DELERY	ROYAL	SHC LEAD BROKEN	REPAIRED	201101911501
11/29/2011	453-043	453-039		DELERY	ROYAL	SHC LEAD BROKEN	REPAIRED	201101911601
11/28/2011	453-043	453-039		DELERY	ROYAL	SHC LEAD BROKEN	REPAIRED	201101911701
11/28/2011	453-043	453-039		DELERY	ROYAL	SHC LEAD BROKEN	REPAIRED	201101911801
11/13/2011	453-051	453-050		DELERY	N RAMPART	SHC LEAD BROKEN	REPAIRED	201101911901
11/13/2011	453-051	453-050		DELERY	N RAMPART	SHC LEAD BROKEN	REPAIRED	201101912001
11/18/2011	453-051	453-050		DELERY	N RAMPART	SEWER MAIN BROKEN	REPAIRED	201101912101
12/4/2011	453-058	453-057		DELERY	CHARTRES	SHC LEAD BROKEN	REPAIRED	201101912201
12/5/2011	453-058	453-057		DELERY	CHARTRES	SHC LEAD BROKEN	REPAIRED	201101912301

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
12/1/2011	453-058	453-057		DELERY	CHARTRES	SEWER MAIN BROKEN	REPAIRED	201101912401
11/30/2011	453-058	453-057		DELERY	CHARTRES	SHC LEAD BROKEN	REPAIRED	201101912501
11/30/2011	453-058	453-057		DELERY	CHARTRES	SEWER MAIN BROKEN	REPAIRED	201101912601
12/5/2011	453-058	453-057		DELERY	CHARTRES	SEWER MAIN BROKEN	REPAIRED	201101913201
11/17/2011	454-047	454-046		ST CLAUDE AV	DELERY	SEWER MAIN BROKEN	REPAIRED	201101913401
11/16/2011	454-050	454-049		ST CLAUDE AV	DELERY	SHC LEAD BROKEN	REPAIRED	201101913501
11/13/2011	455-041	455-039		DELERY	ROCLAY	SHC LEAD BROKEN	REPAIRED	201101913601
12/4/2011	441-035	441-034		CAFFIN AV	N RAMPART	SEWER MAIN BROKEN	REPAIRED	201101914801
11/10/2011	405-038	-035	2306	PIETY	N TONTI	SHC LEAD BROKEN	EXCAVATED	201101916702
12/1/2011	221-014	221-013	6050	CANAL BL	GERMAIN	SHC LEAD BROKEN	REPAIRED	201101926903
11/8/2011			1402	ST BERNARD AV	N VILLERE	SHC LEAD BROKEN	REPAIRED	201101939901
1/12/2011	83-024	-018	2227	JEFFERSON AV	LASALLE	SHC - BACKUP	REPAIRED	201101986902
11/15/2011	83-024	-018	2227	JEFFERSON AV	LASALLE	SHC LEAD BROKEN	REPAIRED	201101986903

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
11/14/2011	442-010	442-009	1406	REYNES	N VILLERE	SEWER MAIN BROKEN	EXCAVATED	201101990902
11/15/2011	442-010	442-009	1406	REYNES	N VILLERE	SEWER MAIN BROKEN	EXCAVATED	201101990904
11/15/2011	346-042	346-037	1836	ST ROCH AV	N PRIEUR	SHC LEAD BROKEN	EXCAVATED	201101992702
11/16/2011	346-042	346-037	1836	ST ROCH AV	N PRIEUR	SHC LEAD BROKEN	EXCAVATED	201101992703
11/30/2011			8524	PLUM	JOLIET	SHC - INSTALL NEW FR(	EXCAVATED	201102014601
12/12/2011			1511	S LIBERTY	TERPSICHORE	SHC LEAD BROKEN	REPAIRED	201102015402
11/18/2011	444-051	444-050	5006	N PRIEUR	REYNES	SHC LEAD BROKEN	REPAIRED	201102033002
11/19/2011			5980	VICKSBURG	POLK AV	SHC LEAD BROKEN	EXCAVATED	201102046902
11/21/2011	222-017	222-002	6332	COLBERT	HARRISON AV	SHC LEAD BROKEN	EXCAVATED	201102047602
11/22/2011	388-066		N/A	HIGGINS BL	MONTEGUT	SMH - COVER BROKEN/I	REPAIRED	201102049801
12/14/2011			6463	MILNE BL	LANE	SEE WHY NO WATER	EXCAVATED	201102060505
12/13/2011			6463	MILNE BL	LANE	SHC LEAD BROKEN	EXCAVATED	201102060502
12/14/2011			6463	MILNE BL	LANE	SHC LEAD BROKEN	REPAIRED	201102060504

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
12/6/2011	299-006	299-005	4501	OWENS BL	ST BERNARD AV	SHC LEAD BROKEN	REPAIRED	201102064703
11/24/2011			6535	COLBERT	LANE	SHC LEAD BROKEN	EXCAVATED	201102065503
11/28/2011			6535	COLBERT	LANE	SHC LEAD BROKEN	REPAIRED	201102065504
11/24/2011			1111	LEBOUEF	DIANA	SHC LEAD BROKEN	EXCAVATED	201102069002
12/7/2011			1111	LEBOUEF	DIANA	SHC LEAD BROKEN	REPAIRED	201102069003
11/25/2011			5583	BELLAIRE DR	I-10 SERVICE RD	SHC LEAD BROKEN	EXCAVATED	201102070303
12/2/2011			5583	BELLAIRE DR	I-10 SERVICE RD	SHC LEAD BROKEN	REPAIRED	201102070304
11/26/2011			5318	WILDAIR DR	FILMORE	SHC LEAD BROKEN	EXCAVATED	201102070602
11/29/2011			5318	WILDAIR DR	RAPIDES DR	SHC LEAD BROKEN	REPAIRED	201102070603
12/1/2011			5980	VICKSBURG	POLK AV	SHC LEAD BROKEN	REPAIRED	201102078902
12/2/2011			402	NASHVILLE AV	ANNUNCIATION	SHC LEAD BROKEN	REPLACED	201102093501
12/2/2011	417-001	-010	2216	BARTHOLOMEW	N MIRO	SHC LEAD BROKEN	REPAIRED	201102093904
12/3/2011			3010	GEN OGDEN	FIG	SHC LEAD BROKEN	EXCAVATED	201102123002

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
12/3/2011			5379	CHATHAM DR	FILMORE AV	SHC LEAD BROKEN	EXCAVATED	201102124802
12/7/2011			5379	CHATHAM DR	FILMORE AV	SHC LEAD BROKEN	REPAIRED	201102124803
12/3/2011			4704	ANNETTE	CARNOT	SHC LEAD BROKEN	EXCAVATED	201102125502
12/9/2011			4704	ANNETTE	CARNOT	SHC LEAD BROKEN	EXCAVATED	201102125503
12/19/2011			4704	ANNETTE	CARNOT	SHC LEAD BROKEN	EXCAVATED	201102125504
12/20/2011			4704	ANNETTE	CARNOT	SHC LEAD BROKEN	REPAIRED	201102125506
12/4/2011			2041	SELMA	TOURO	SHC LEAD BROKEN	EXCAVATED	201102126802
12/8/2011			2041	SELMA	TOURO	SHC LEAD BROKEN	REPAIRED	201102126803
12/4/2011			5645	BELLAIRE DR	I-10 SERVICE RD	SHC LEAD BROKEN	EXCAVATED	201102127402
12/8/2011			5917	CONSTANCE	ELEONORE	SHC LEAD BROKEN	EXCAVATED	201102148503
12/9/2011			5917	CONSTANCE	ELEONORE	SHC LEAD BROKEN	REPLACED	201102148504
12/8/2011			4822	CERISE AV	HAMMOND	SHC LEAD BROKEN	REPAIRED	201102153202
12/21/2011			862	TCHOUPITOULAS	ST JOSEPH	SHC LEAD BROKEN	REPAIRED	201102157702

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
12/19/2011			2109	JOSEPHINE	S SARATOGA	SHC - INSTALL NEW FR(	REPAIRED	201102157801
12/9/2011			4309	RANDOLPH	MANDOLIN	SHC LEAD BROKEN	REPAIRED	201102158702
12/12/2011	293-P7	293-V4SS	N/A	ST BERNARD AV	ST DENIS	SEWER LEAK - FORCE M	EXCAVATED	201102163802
12/13/2011	297-P1	293-P7	N/A	ST BERNARD AV	ST DENIS	SEWER MAIN BROKEN	REPAIRED	201102163805
12/14/2011	297-P1	293-P7	N/A	ST BERNARD AV	ST DENIS	SEWER MAIN BROKEN	REPAIRED	201102163806
12/12/2011			709	GEN PERSHING	CONSTANCE	SHC LEAD BROKEN	EXCAVATED	201102166802
12/14/2011			709	GEN PERSHING	CONSTANCE	SHC LEAD BROKEN	REPAIRED	201102166805
12/13/2011			709	GEN PERSHING	CONSTANCE	SHC LEAD BROKEN	EXCAVATED	201102166803
12/11/2011			1731	ROBERT	DANNEEL	SHC LEAD BROKEN	REPAIRED	201102167702
12/21/2011	464-084	-085	4643	CAMELIA	RANSOM	SHC LEAD BROKEN	EXCAVATED	201102179603
12/22/2011			4643	CAMELIA	RANSOM	SHC LEAD BROKEN	REPAIRED	201102179604
12/14/2011			2515	MAGNOLIA	2ND	SHC LEAD BROKEN	REPAIRED	201102183302
12/15/2011			2515	MAGNOLIA	2ND	SHC LEAD BROKEN	REPAIRED	201102183304

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
12/15/2011			3324	MILAN	S PRIEUR	SHC LEAD BROKEN	REPAIRED	201102184302
12/18/2011			6601	MILNE BL	PORTEOUS	SHC LEAD BROKEN	EXCAVATED	201102186702
12/29/2011			6601	MILNE BL	PORTEOUS	SHC LEAD BROKEN	EXCAVATED	201102186704
12/30/2011			6601	MILNE BL	PORTEOUS	SHC LEAD BROKEN	REPAIRED	201102186706
12/15/2011			4370	MAPLE LEAF DR	WOODLAND DR	SHC LEAD BROKEN	REPAIRED	201102192402
12/19/2011			4370	MAPLE LEAF DR	WOODLAND DR	SHC LEAD BROKEN	REPAIRED	201102192406
12/20/2011	196-021	196-010	706	CANAL		SHC LEAD BROKEN	EXCAVATED	201102192702
12/21/2011	196-021	196-010	706	CANAL		SHC LEAD BROKEN	REPAIRED	201102192703
12/17/2011			4782	CITRUS DR	HAMMOND	SHC LEAD BROKEN	EXCAVATED	201102198102
12/20/2011			4782	CITRUS DR	HAMMOND	SHC LEAD BROKEN	REPAIRED	201102198103
12/16/2011			1711	FRENCHMEN	N DERBIGNY	SHC LEAD BROKEN	EXCAVATED	201102198402
12/20/2011			1711	FRENCHMEN	N DERBIGNY	SHC LEAD BROKEN	EXCAVATED	201102198403
12/21/2011			1711	FRENCHMEN	N DERBIGNY	SHC LEAD BROKEN	REPAIRED	201102198404

Total Collection System Repairs In 2011 By SWB

C DATE	STRUC1	STRUC2	ADDR	STREET	CROSS STREET	PROBLEM	ACTION	WO NO
12/17/2011			6657	FLEUR DE LIS DR	38TH	SHC LEAD BROKEN	EXCAVATED	201102202502
12/27/2011			6657	FLEUR DE LIS DR	38TH	SHC LEAD BROKEN	REPAIRED	201102202504
12/22/2011			6657	FLEUR DE LIS DR	38TH	SHC LEAD BROKEN	EXCAVATED	201102202503
12/28/2011			6147	WEST END BL	RINGOLD	SHC - BACKUP	EXCAVATED	201102205001
12/29/2011			6147	WEST END BL	RINGOLD	SHC LEAD BROKEN	REPAIRED	201102205003
12/28/2011			124	S CLARK		SHC LEAD BROKEN	REPLACED	201102220102
12/28/2011			128	S CLARK		SHC LEAD BROKEN	REPLACED	201102220702
12/22/2011	327-009	327-007	2000	FRENCHMEN	N JOHNSON	SHC LEAD BROKEN	REPAIRED	201102238602
12/26/2011	327-009	327-007	2000	FRENCHMEN	N JOHNSON	SHC LEAD BROKEN	EXCAVATED	201102238603
12/24/2011			3516	MEADOW PARK L	TIMBER RIDGE DR	SHC LEAD BROKEN	REPAIRED	201102278803
12/28/2011			2500	CLARA		SHC LEAD BROKEN	REPLACED	201102297002

TOTAL REPAIRS **1,077**